

FILE



RECEIVED-DOCKETING DIV

76 South Main Street
Akron, Ohio 44308

2018 DEC 24 PM 2:57

1-800-646-0400

December 20, 2018

PUCO

Ms. Barcy F. McNeal
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

PRE-APPLICATION NOTIFICATION LETTER
Brookside-Leaside 138 kV Transmission Line Switch Structure Addition Project
Case No. 18-1396-EL-BNR

Dear Ms. McNeal:

In accordance with Ohio Administrative Code ("OAC") Rule 4906-6-03(A) and OAC Chapter 4906-6 generally, this letter will serve as the pre-application notice letter of applicant American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, for the above referenced Project. ATSI expects to file a Construction Notice application with the Ohio Power Siting Board shortly.

In this Project, ATSI proposes to add two (2) switch structures to the Brookside-Leaside 138 kV Transmission Line, on the same centerline as the existing transmission line. The new switch structures will be single pole wood structures, one on each side of the existing tap structure to Milliron Substation. Two (2) temporary single circuit wood pole structures will also be installed for a temporary 138 kV transmission connection approximately 400 feet in length to Milliron Substation during this Project's construction. The Project will be located in Jackson Township, Richland County Ohio.

Construction on this Project is expected to begin as early as April 15, 2019 and be completed by June 1, 2019.

Sincerely,

Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

This is to certify that the images appearing are an accurate and complete reproduction of a copy file document delivered in the regular course of business.
Technician WST Date Processed 12/24/18