

Case No. 18-1732-EL-REN

Gregory and Michele Paulin


Staff Interrogatories – Initial Set

Question 1:

In section N.1 you state that meter manufacturer is Solar Edge type SE76000 A-US. The specification sheet of the SE7600 states that utility grade monitoring is "optional." Does this inverter have the revenue grade option? If so, please provide proof to this extent. If not, how will the facility meet the utility grade meter requirement?

Response:

The inverter is integrated with a revenue grade meter, as demonstrated in the photos below. The photos display a layout of the inverter & revenue grade meter as well as the inverter reading. The inverter screen will only read “Production Meter” on SolarEdge inverters that have the revenue grade meters installed.



SOLAR ARRAY INSTALLED BY:



Whole Sun
DESIGNS^{LLC}

(812) 550-1251

WWW.WHOLESUNDESIGNS.COM

Production Meter
Status: <OK>
Power[W]: 0.0
Energy[KWh]: 273.782



This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

12/29/2018 2:27:38 PM

in

Case No(s). 18-1732-EL-REN

Summary: Response Response to Staff Interrogatory - Initial Set electronically filed by Mr. Steven Eisenberg on behalf of Gregory Paulin and Michele Paulin