

Case No. 18-1698-EL-REN  
McClintic, Gary Residence - Orleans Elementary  
Staff Interrogatories - Initial Set

Question 1: In section I.1 the nameplate capacity is listed as 499.2 kW. But in section G.1 you state the facility has 1,566 320 watt panels. Since  $1,566 \times 320W = 501.12 \text{ kW}$ . Is the nameplate capacity 501.12 kW?

**Answer 1: The nameplate capacity is confirmed at 501.12 kW. If possible, please also alter the Facility Name to correctly reflect the facility, which is Orleans Community Schools – Orleans Elementary.**

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**1/23/2019 2:19:16 PM**

**in**

**Case No(s). 18-1698-EL-REN**

Summary: Response Response to Staff Interrogatories – Initial Set for McClintic, Gary  
Residence - Orleans Elementary electronically filed by Mr. Steven Eisenberg on behalf of  
Orleans Community Schools