



COLUMBUS | CLEVELAND  
CINCINNATI | DAYTON  
MARIETTA

**BRICKER & ECKLER LLP**  
100 South Third Street  
Columbus, OH 43215-4291  
MAIN: 614.227.2300  
FAX: 614.227.2390

www.bricker.com  
info@bricker.com

**Devin D. Parram**  
614.227.8813  
dparram@bricker.com

February 19, 2019

*Via Electronic Filing*

Ms. Barcy McNeal  
Administration/Docketing  
Ohio Power Siting Board  
180 East Broad Street, 11<sup>th</sup> Floor  
Columbus, Ohio 43215-3793

**Re: The East Ohio Gas Company d/b/a Dominion Energy Ohio  
Construction Notice for Line 2925 Phase 3  
Case No. 19-176-GA-BNR**

Dear Ms. McNeal:

Attached is a copy of The East Ohio Gas Company d/b/a Dominion Energy Ohio's responses to the Ohio Power Siting Board Staff's first set of data requests.

Please feel free to contact me if you have any questions.

Sincerely,

Devin D. Parram

Attachment

cc: Ashton Holderbaum (w/Attachment)

**The East Ohio Gas Company d/b/a Dominion Energy Ohio (“DEO”)  
Construction Notice for Line 2925 Phase 3 Pipeline Replacement Project  
Case No. 19-176-GA-BNR**

**Responses to Staff’s First Data Request**

1. The capacity modeling data of the pipeline currently and with the upgrade.

**RESPONSE:**

- a. 8” capacity = 120,000 mcf/d
- b. 12” capacity = 265,000 mcf/d
- c. Note: Based on a MAOP of 1565 psig. The pipeline pressure may range between = 1555 psig and 200 psig

2. The % operating capacity expected at peak day.

**RESPONSE:**

- a. 8” = 60%
- b. 12” = 25%
- c. Note: Above percentages based on normal operations.

3. Why they must use ILI instead of the alternatives.

**RESPONSE:**

*ILI provides detailed information of the internal defects of the pipeline including corrosion, cracks and deformation. The alternative, hydrostatic testing does not provide a comprehensive internal inspection. It merely determines whether a line is defective. Also, ILI allows DEO to clean the line during the inspection and allows the pipeline to be inspected without interrupting operation of the pipeline. Hydrostatic testing does not provide for either one of these benefits. Please confirm the existing line has no protective coating.*

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**2/19/2019 12:01:33 PM**

**in**

**Case No(s). 19-0176-GA-BNR**

Summary: Response of The East Ohio Gas Company d/b/a Dominion Energy Ohio Staff's First Set of Data Requests electronically filed by Teresa Orahoud on behalf of Devin D. Parram