



Public Utilities Commission

Ohio Certified Solar Facility Update Form

Use this form to provide updated information for facilities that have been certified in Ohio. For new applications use the [online application](#).

Case No.:
17-0877-EL-REN

G.3. Please submit digital photographs that depict an accurate characterization of the renewable generating facility. **Please indicate the date(s) the photographs were taken.** For existing facilities, these photographs must be submitted for your application to be reviewed. For proposed facilities or those under construction, photographs will be required to be filed within 30 days of the on-line date of the facility.

G.4 SOLAR PHOTOVOLTAIC (total and specifications for the **expansion only**)

G.4a Location of the PV array: ☒ Roof ☐ Ground ☐ Other

G.4b Total number of Modules: 17

G.4.1 PV Modules

For each PV module, provide the following information:

G.4.1.a Manufacturer: Canadian Solar

G.4.1.b Model and Rating: CS6K-275 M and 275

I. Facility Information

I.a The nameplate capacity of the entire facility in megawatts (MW): .017875 (**new total system size**)

I.1 For each generating unit, provide the following information: (first row is for original system, 2nd and 3rd rows for expansions)

Unit In-Service Date	Capacity (MW)	Annual Generation (MWh)
3-10-2017	.0132	1:1
6-2018	.004675	1:1

If a new meter(s) has been installed update this section as well. If the expansion causes the facility to have a nameplate capacity over 6 kW the facility will need a utility grade meter if it does not already utilize one.

N. Meter Specifications

Metering Requirements

If the renewable energy resource generating facility is 6 kW or below, the output may be measured with either an inverter meter or a utility grade meter.

All facilities that are larger than 6 kW must measure the output of the facility with a utility grade meter. Facilities that are larger than 6 kW and that are not measuring output with a utility grade meter will not be certified. OAC 4901:1-40-04 (D)(1)

Please only report on the meter or the meters used to measure the output from the facility which will be reported to the attribute tracking system.

N.a The meter(s) that are measuring output from the facility are:

☐ Inverter Meter(s)

☒ Utility Grade Meter(s)

N.1 Please provide the following information for each meter used in your system.

N.1.a Manufacturer: Centron

N.1.b Serial Number: 65260104

N.1.c Type: CL 200

N.1.d Date of Last Certification: 3-10-2017

Attach a photograph of the meter(s) with date image taken. The meter reading(s) must be clearly visible in the photograph.

N.1.e Report the total meter reading number at the time the photograph was taken and specify the appropriate unit of generation (e.g., kWh): 40,160

Date photograph taken: 3-6-2019

INSERT PHOTOGRAPH(S)





Dashboard

Choose a site (insert at least 3 letters to search):

COOK PV

Overview

Current Power	Energy today	Energy this month	Lifetime Energy
8.29 kW	19.06 kWh	225.63 kWh	40.16 MWh




Power and Energy

Day Week **Month** Billing Cycle Year

03/01/2019 - 03/31/2019

System Production: 225.63 kWh

Wh



Site Summary

ID 487390
Name COOK PV
Country United States
State Ohio
City Mount Orab
Address Barony Lane 105
Installed 02/16/2017
Last Updated 03/06/2019 11:11
Peak Power 13.2 kWp

Weather



Mostly Sunny
17 °F
Feels like 11 °F
Wind SSW, 4 MPH
Humidity 67 %
Sunrise at 07:02
Sunset at 18:34





This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/6/2019 11:27:50 AM

in

Case No(s). 17-0877-EL-REN

Summary: Amended Application 17-0877-EL-REN: System Expansion electronically filed by Mr. Avery Sellers on behalf of Cook Family Trust