

May 9, 2019

Ms. Barcy F. McNeal
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793


**Wood County 138 kV Transmission Line
Reinforcement Project
Case No. 18-1335-EL-BTX**

Dear Ms. McNeal,

This letter provides supplemental information to the Board concerning the construction of the Wood County 138 kV Transmission Line Reinforcement Project, Case No. 18-1335-EL-BTX. At the time of filing, a conductor type of 556.5 kcmil 26/7 ACSR was proposed. Subsequent to the initial filing, ATSI updated its internal standards and conductor type to 795 kcmil 26/7 ACSR is now proposed for the Project. This change in conductor does not substantially alter any aspect nor increase the expected impacts of the Project.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2526.

Sincerely,



Scott M. Humphrys
Transmission Siting Supervisor
Energy Delivery Transmission and Substation
Design
FirstEnergy Service Company

cc: J. O'Dell

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

5/9/2019 4:05:31 PM

in

Case No(s). 18-1335-EL-BTX

Summary: Notice of the Filing of Supplemental Information for Project electronically filed by Mr. Robert J Schmidt on behalf of American Transmission Systems Inc.