

Case No. 19-1033-EL-REN
GOJO
Staff Interrogatories – Initial Set

Question 1: In Section I.a. of the application, the nameplate capacity is listed as 525 kW. However, in section G.1 you state that the system has 1,836 345 watt panels which would give you a nameplate capacity of 633.42 kW. Is the nameplate capacity 633.42 kW? If not, please explain how the nameplate capacity was determined.

Answer 1: 525 kW is the AC rated capacity, 633.42 is the correct nameplate capacity of the installed system in kW DC.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

5/22/2019 3:56:45 PM

in

Case No(s). 19-1033-EL-REN

Summary: Reply Reply to Case No. 19-1033-EL-REN Staff Interrogatories – Initial Set
electronically filed by Mr. Ty Scott on behalf of Marting, Thomas A Mr. and GOJO