


System Components
 Modules: (151) Axitec 330, 49.83 kW
 Inverter: (2) SE 20K-US
 Optimizer: (76) SE P860
 Racking: IronRidge-Roof Mtd.
 Attachment: S5! V-Mini
 Standing seam



LEGEND



SOLAR ARRAY AZIMUTH
 165°
 Roof Slope: 15°



PARADISE ENERGY SOLUTIONS

RODENE FARMS LLC - 1361 CR 108 Sugarcreek, OH 44681

BY:MJP DATE:8/6/19 Rodene Farms LLC.dwg

SYSTEM LAYOUT PLAN

SHEET 1 OF 1

SCALE: NTS

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

11/27/2019 11:27:54 AM

in

Case No(s). 19-2052-EL-REN

Summary: Response electronically filed by Mr. Andrew S Conway on behalf of Rodene Farms