

June 15, 2020

Ms. Tanowa Troupe
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

PRE-APPLICATION NOTIFICATION LETTER
Juniper-Jennings 138 kV Q-15 and Juniper-Newburgh 138 kV Q-18 Transmission Lines
Structure Addition Project
Case No. 20-1075-EL-BNR

Dear Ms. Troupe:

In accordance with Ohio Administrative Code (“OAC”) Rule 4906-6-03(A) and OAC Chapter 4906-6 generally, this letter will serve as the pre-application notice letter of applicant American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, for the above referenced Project. Applicant expects to file a Construction Notice application shortly.

Due to the removal of the Hillside Switching Station, ATSI proposes to add two (2) double circuit steel monopole structures on drilled shaft foundations to the existing Juniper-Jennings 138 kV Q-15 and Juniper-Newburgh 138 kV Q-18 Transmission Lines. These structures are required to provide support to the transmission lines when the existing lattice deadend structures are demolished as part of the removal of the station. The Project will be located in the City of Independence, Cuyahoga County, Ohio.

Construction on this Project is expected to begin as early as October 1, 2020 and be completed by December 17, 2020, if approved by the Board.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/15/2020 9:41:09 AM

in

Case No(s). 20-1075-EL-BNR

Summary: Notice of Docketing of Pre-application Notification Letter for Project electronically filed by Mr. Robert J Schmidt on behalf of American Transmission Systems Inc.