

**BEFORE
THE PUBLIC UTILITIES COMMISSION OF OHIO**

In the Matter of the Application for Certification)	
As an Ohio Renewable Energy Resource Generation)	Case No. 21-0085-EL-REN
Facility for Clear Creek Wind)	

**REVIEW AND RECOMMENDATION
SUBMITTED ON BEHALF OF THE STAFF OF
THE PUBLIC UTILITIES COMMISSION OF OHIO**

CASE HISTORY

On January 21, 2021, a representative submitted an application on behalf of Tenaska Clear Creek Wind, LLC (Applicant) for certification of Clear Creek Wind (Facility).¹ The representative also supplemented the application with a PJM Distribution Factor Analysis (DFAX).

The Facility is located in Maryville, Missouri. Comprised of one hundred-eleven Vestas wind turbines, the aggregate capacity of the Facility is 242 megawatts. According to the application, the Facility was placed into service in May 2020.

An Attorney Examiner Entry issued on January 28, 2021, suspended the automatic approval process for this case.

STAFF REVIEW

The Staff's consideration of applications for certification of a renewable energy resource facility consists primarily, but not exclusively, of three statutory criteria: (1) the deliverability of the facility's output to the state of Ohio, (2) the resource/technology used at the facility, and (3) the facility's placed in-service date.

¹ The Applicant's representative submitted its application on January 21, 2021, and Staff initiated a case to consider the application on the Commission's Docketing Information System on January 25, 2021.

1) Deliverability

Under R.C. 4928.64(B)(3), a qualifying renewable energy resource must either have a facility located in Ohio, or be deliverable into Ohio. Further, Ohio Administrative Code (Ohio Adm.Code) 4901:1-40-01(F) defines “deliverable into this state” as follows:

"Deliverable into this state" means that the electricity or qualifying biologically derived methane gas originates from a facility within a state contiguous to Ohio. It may also include electricity originating from other locations, pending a demonstration that the electricity is physically deliverable to the state.

Because the Facility is a grid-connected facility located in Missouri, a state not contiguous to Ohio, Staff concludes that the Applicant would need to provide sufficient documentation to demonstrate physical deliverability to Ohio consistent with the approach first established in Case No. 09-0555-EL-REN. In 09-0555-EL-REN, the Commission accepted the Staff’s proposed approach requiring that the absolute value of a facility’s impact on a transmission line in Ohio must be greater than 5 percent and greater than 1 megawatt (MW), as determined by an adequate power flow study.

The Applicant’s representative provided a DFAX power flow study which was performed by PJM Interconnection, LLC. The DFAX analysis assumed a 50/50 peak load forecast for the 2025 Regional Transmission Expansion Plan Base Case. The DFAX study evaluated the impacts of power flows from the Facility’s injection of energy on approximately 3,000 electric system transmission facilities in Ohio and the surrounding areas.

The highest DFAX value (**9.76%**) within the state of Ohio occurred on American Electric Power’s Maliszewski-Vassel 765 kilovolt transmission line. The value meets the greater than five percent transmission line impact criterion.

Multiplying the highest DFAX value by the Facility’s nameplate capacity results in a value of **23.62 MWs**, which satisfies the greater than 1 MW criterion.²

As the Facility satisfies both the 5 percent and 1 MW criteria, Staff concludes that the Facility is physically deliverable to the state of Ohio.

² 0.0976 * 242 = 23.62 MW

2) Resource/Technology

The R.C. defines “renewable energy resource” for purposes of the state’s renewable portfolio standard (RPS).³ This statutory definition of a renewable energy resource includes wind power, and therefore Staff concludes that the Facility satisfies the resource/technology provision of the statute.

3) Placed In-Service Date

The Facility must satisfy one of the applicable statutory provisions pertaining to the placed in-service date.⁴ With all of the Facility’s wind turbines having been placed in-service after January 1, 1998, Staff finds that the Facility satisfies the applicable placed in-service date requirement.

4) Additional Considerations

- (a) For electric generating facilities, Commission rules require that facilities above 6 kilowatts measure their renewable output with a utility-grade meter.⁵ The meter described in the application satisfies this rule requirement.
- (b) The Facility must be registered with either M-RETS or PJM EIS’ GATS, the two attribute tracking systems currently recognized by the Commission. The application indicates that the Facility will be registered on GATS.

STAFF RECOMMENDATION

Staff has completed its review of the application and any supplemental information provided by the Applicant. Staff has determined that the Facility appears to satisfy the Commission’s requirements for certification as a renewable energy facility. Staff recommends that the Facility be certified.

³ R.C. 4928.01(A)(37)

⁴ R.C. 4928.64(A)(1)

⁵ Ohio Adm.Code 4901:1-40-04(C)(2)(e).

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

2/19/2021 11:35:41 AM

in

Case No(s). 21-0085-EL-REN

Summary: Staff Review and Recommendation electronically filed by Mr. Stuart M Siegfried on behalf of PUCO Staff