

**BEFORE
THE OHIO POWER SITING BOARD**

In the Matter of the Application of Clearview Solar)	
I, LLC for a Certificate of Environmental)	
Compatibility and Public Need to Construct a Solar-)	Case No: 20-1362-EL-BGN
Powered Electric Generation Facility in Champaign)	
County, Ohio.)	

JOINT STIPULATION AND RECOMMENDATION

I. INTRODUCTION

Clearview Solar I, LLC (“Applicant”), the Board of County Commissioners of Champaign County (“County Commissioners”), the Ohio Farm Bureau Federation (“OFBF”), and the Ohio Power Siting Board (“Board”) Staff (“Staff”) (jointly referred to herein as “Signatory Parties”) submit this Joint Stipulation and Recommendation (“Stipulation”) for adoption by the Board. Ohio Adm.Code 4906-2-24(A) provides that any two or more parties to a proceeding may enter into a written stipulation covering the issues presented in such a proceeding. The purpose of this document is to set forth the understanding and agreement of the parties who have signed below, and to jointly recommend that the Board approve and adopt this Stipulation as part of its Opinion, Order, and Certificate in this proceeding, resolving all matters pertinent to the certification and construction of the solar-powered electric generation facility in Adams Township, Champaign County, Ohio as proposed in this proceeding.

The County Commissioners and the OFBF filed motions to intervene in this proceeding, which were granted by the Administrative Law Judges (“ALJs”) on June 17, 2021. The Report of Investigation was issued by the Staff on May 24, 2021 (“Staff Report”). The first local public hearing was held June 8, 2021. The second local public hearing was held on August 19, 2021. The evidentiary hearing on July 1, 2021, was called and continued to September 1, 2021.

This Stipulation is supported by adequate data and information; represents a just and reasonable resolution of issues in this proceeding; violates no regulatory principle or precedent; and is the product of lengthy, serious bargaining among knowledgeable and capable parties in a cooperative process to resolve all of the issues in this proceeding. This Stipulation represents the culmination of these discussions, and the Signatory Parties acknowledge that this agreement is amply supported by the record and, thus, entitled to careful consideration by the Board. Accordingly, the Signatory Parties recommend that the Board issue a Certificate of Environmental Compatibility and Public Need for the facility.

II. JOINT RECOMMENDATIONS OF THE SIGNATORY PARTIES

A. Recommended Conditions

The proposed facility is located in Champaign County, Ohio and its total generating capacity will not exceed 144 megawatts alternating current (“MW”). Construction of the facility is expected to begin as early as first quarter of 2022.

The Signatory Parties recommend that the Board issue the Certificate of Environmental Compatibility and Public Need requested by the Applicant subject to the following conditions:

- (1) The Applicant shall install the facility, utilize equipment and construction practices, and implement mitigation measures as described in the application and as modified and/or clarified in supplemental filings, replies to data requests, and recommendations in the *Staff Report of Investigation*.
- (2) The Applicant shall conduct a preconstruction conference prior to the commencement of any construction activities. Staff, the Applicant, and representatives of the primary contractor and all subcontractors for the project shall attend the preconstruction conference. The conference shall include a presentation of the measures to be taken by the Applicant and contractors to ensure compliance with all conditions of the certificate, and discussion of the procedures for on-site investigations by Staff during construction. Prior to the conference, the Applicant shall provide a proposed conference agenda for Staff review. The Applicant may conduct separate preconstruction conferences for each stage of construction.

- (3) Within 60 days after the commencement of commercial operation, the Applicant shall submit to Staff a copy of the as-built specifications for the entire facility. If the Applicant demonstrates that good cause prevents it from submitting a copy of the as-built specifications for the entire facility within 60 days after commencement of commercial operation, it may request an extension of time for the filing of such as-built specifications. The Applicant shall use reasonable efforts to provide as-built drawings in both hard copy and as geographically referenced electronic data.
- (4) The certificate shall become invalid if the Applicant has not commenced a continuous course of construction of the proposed facility within five years of the date of journalization of the certificate unless the Board grants a waiver or extension of time.
- (5) As the information becomes known, the Applicant shall file in this proceeding the date on which construction will begin, the date on which construction was completed, and the date on which the facility begins commercial operation.
- (6) Prior to the commencement of construction activities in areas that require permits or authorizations by federal or state laws and regulations, the Applicant shall obtain and comply with such permits or authorizations. The Applicant shall provide copies of permits and authorizations, including all supporting documentation, to Staff within seven days of issuance or receipt by the Applicant. The Applicant shall provide a schedule of construction activities and acquisition of corresponding permits for each activity at the preconstruction conference.
- (7) The certificate authority provided in this case shall not exempt the facility from any other applicable and lawful local, state, or federal rules or regulations nor be used to affect the exercise of discretion of any other local, state, or federal permitting or licensing authority with regard to areas subject to their supervision or control.
- (8) At least 30 days prior to the preconstruction conference, the Applicant shall submit to Staff, for review and acceptance, one set of detailed engineering drawings of the final project design and mapping in the form of PDF, which the Applicant shall also file on the docket of this case, and geographically referenced data (such as shapefiles or KMZ files) based on final engineering drawings to confirm that the final design is in conformance with the certificate. Mapping shall include the limits of disturbance, permanent and temporary infrastructure locations, areas of vegetation removal and vegetative restoration as applicable, and specifically denote any adjustments made from the siting detailed in the application. All final geotechnical study results shall be included in this submission. The detailed engineering drawings of the final project design shall account for geological features and include the identity of the registered professional engineer(s), structural engineer(s), or engineering firm(s), licensed to practice engineering in the state of Ohio who reviewed and approved the designs.

- (9) Separate preconstruction conferences may be held for the different phases of civil construction and equipment installation. At least 30 days prior to each preconstruction conference, the Applicant shall submit to Staff, for review and acceptance, one set of detailed engineering drawings of the final project design for that phase of construction and mapping in the form of PDF, which the Applicant shall also file on the docket of this case, and geographically referenced data (such as shapefiles or KMZ files) based on final engineering drawings to confirm that the final design is in conformance with the certificate. Mapping shall include the limits of disturbance, permanent and temporary infrastructure locations, areas of vegetation removal and vegetative restoration as applicable, and specifically denote any adjustments made from the siting detailed in the application. The detailed engineering drawings of the final project design for each phase of construction shall account for geological features and include the identity of the registered professional engineer(s), structural engineer(s), or engineering firm(s), licensed to practice engineering in the state of Ohio who reviewed and approved the designs. All applicable geotechnical study results, and stormwater and drainage plans shall be included in the submission of the final project design to Staff.
- (10) A least 30 days prior to the preconstruction conference, the Applicant shall provide Staff, for review and acceptance, the final geotechnical engineering report. This shall include a summary statement addressing the geologic and soil suitability. This shall also include a summary statement explaining what special considerations were given to the seismic activity and fault system within the region and an evaluation of its potential impacts during construction and operation of the proposed solar facility.
- (11) At least 30 days prior to the start of construction, the Applicant shall file a copy of the final complaint resolution plan on the public docket. At least seven days prior to the start of construction and at least seven days prior to the start of facility operations, the Applicant shall notify via mail affected property owners and tenants including those individuals who were provided notice of the public informational meeting, residences located within one mile of the project area, parties to this case, county commissioners, township trustees, emergency responders, airports, schools, and libraries, as well as anyone who has requested updates regarding the project. These notices shall provide information about the project, including contact information and a copy of the complaint resolution plan. The start of construction notice shall include written confirmation that the Applicant has complied with all preconstruction-related conditions of the certificate, as well as a timeline for construction and restoration activities. The start of facility operations notice shall include written confirmation that the Applicant has complied with all construction-related conditions of the certificate, as well as a timeline for the start of operations. The Applicant shall file a copy of these notices on the public docket. During the construction and operation of the facility, the Applicant shall submit to Staff a complaint summary report by the fifteenth day of April, July, October, and January of each year through the first five years of operation. The report shall include a list

of all complaints received through the Applicant's complaint resolution process, a description of the actions taken toward the resolution of each complaint, and a status update if the complaint has yet to be resolved.

- (12) The Applicant shall not commence any construction of the facility until it has executed an Interconnection Service Agreement and Interconnection Construction Service Agreement with PJM Interconnection, which includes construction, operation, and maintenance of system upgrades necessary to integrate the proposed generating facility into the regional transmission system reliably and safely. The Applicant shall docket in the case record a letter stating that the Agreement has been signed or a copy of the executed Interconnection Service Agreement and Interconnection Construction Service Agreement.
- (13) The facility shall be operated in such a way as to assure that no more than 144 megawatts would be injected into the Bulk Power System at any time.
- (14) Prior to commencement of construction, the Applicant shall prepare a landscape and lighting plan in consultation with a landscape architect licensed by the Ohio Landscape Architects Board that addresses the aesthetic and lighting impacts of the facility with an emphasis on any locations where an adjacent non-participating parcel contains a residence with a direct line of sight to the project area and also include a plan describing the methods to be used for fence repair. The plan shall include measures such as fencing, vegetative screening or good neighbor agreements. Unless alternative mitigation is agreed upon with the owner of any such adjacent, non-participating parcel containing a residence with a direct line of sight to the fence of the facility, the plan shall provide for the planting of vegetative screening designed by the landscape architect to enhance the view from the residence and be in harmony with the existing vegetation and viewshed in the area. The Applicant shall adjust its landscaping and lighting plan to incorporate a third-tier planting module, or other appropriate planting measures, to address impacts to the traveling public, nearby communities, and recreationalists. The Applicant shall maintain vegetative screening for the life of the facility and the Applicant shall replace any failed plantings so that, after five years, at least 90 percent of the vegetation has survived. The Applicant shall maintain all fencing along the perimeter of the project in good repair for the term of the project and shall promptly repair any damage as needed. Lights shall be motion-activated and designed to narrowly focus light inward toward the facility, such as being downward-facing and/or fitted with side shields. The Applicant shall provide the plan to Staff for review and confirmation that it complies with this condition.
- (15) Prior to commencement of construction, the Applicant shall submit to Staff for approval a solar panel perimeter fence type that is both wildlife permeable and aesthetically fitting for a rural location, and meets all applicable electrical codes. This condition shall not apply to substation fencing.

- (16) General construction activities shall be limited to the hours of 7:00 a.m. to 7:00 p.m., or until dusk when sunset occurs after 7:00 p.m. Impact pile driving shall be limited to the hours between 9:00 a.m. and 7:00 p.m. or until dusk when sunset occurs after 7:00 p.m. Impact pile driving may occur between 7:00 a.m. and 9:00 a.m. if the noise impact at non-participating receptors is not greater than daytime ambient Leq plus 10 dBA. If impact pile driving is required between 7:00 a.m. and 9:00 a.m., the Applicant shall install a noise monitor in a representative location to catalog that this threshold is not being exceeded. Hoe ram operations, if required, shall be limited to the hours between 10:00 a.m. and 4:00 p.m., Monday through Friday. HDD operations if started during general construction activities hours may continue until the completion of the HDD activity. Construction activities that do not involve noise increases above ambient levels at sensitive receptors are permitted outside of daylight hours when necessary. The Applicant shall notify property owners or affected tenants within the meaning of Ohio Adm.Code 4906-3-03(B)(2) of upcoming construction activities including potential for nighttime construction.
- (17) If the inverters or substation transformer chosen for the project have a higher sound power output than the models used in the noise model, the Applicant shall show with modeling that sound levels will not exceed the daytime ambient level plus five dBA at any non-participating sensitive receptor, the results of which will be submitted at least 30 days prior to construction. If noise data is not available from the inverter or transformer manufacturer, an operational noise test may be performed to comply with this condition. The test must be performed during a sunny day in the months of May-August, at a distance equal to the minimum distance from an inverter to a non-participating residence. If the test shows the operational noise level is greater than project area ambient Leq level plus five dBA additional noise mitigation will be required. This condition is complied with if the test shows the operational noise level is less than project area ambient Leq level plus five dBA.
- (18) With respect to the 150-acre area(s) identified within its May 3, 2021 data request response where potential archaeological resources remain to be surveyed, the Applicant shall continue to comply with its Programmatic Agreement with the Ohio State Preservation Office (“OHPO”) dated March 19, 2021 (“Programmatic Agreement”). Pursuant to the Programmatic Agreement, the Applicant shall complete the remaining surveys and submit, no later than July 15, 2021, a supplement to its Phase I Archeological Survey Report dated May 12, 2021 (“Phase I Report”), that provides the additional survey results to OHPO and Staff for their review and concurrence (“Phase I Supplement”). The Applicant will avoid, any adverse effects to archeological resources for the Project, including any identified within the additional 150-acre, in its final site plan for the Project any archeological resources identified in the Phase I Report or the Phase I Supplement as potentially eligible for listing on the National Register of Historic Places.

- (19) The Applicant shall avoid, where possible, or minimize to the extent practicable, any damage to functioning field tile drainage systems and soils resulting from the construction, operation, and/or maintenance of the facility in agricultural areas. Damaged field tile systems shall be promptly repaired to at least original conditions or modern equivalent at the Applicant's expense. However, if the affected landowner agrees to not having the damaged field tile system repaired, they may do so only if the field tile systems of adjacent landowners and public rights-of-way remain unaffected by the non-repair of the landowner's field tile system.
- (20) If the Applicant encounters any new listed plant or animal species or suitable habitat of these species prior to construction, the Applicant shall include the location in the final engineering drawings and associated mapping, as required in condition 8. The Applicant shall avoid impacts to these species and explain how impacts would be avoided during construction.
- (21) The Applicant shall adhere to seasonal cutting dates of October 1 through March 31 for the removal of trees three inches or greater in diameter to avoid impacts to Indiana bats and northern long-eared bats, unless coordination with the Ohio Department of Natural Resources ("ODNR") and the U.S. Fish and Wildlife Service ("USFWS") allows a different course of action.
- (22) The Applicant shall have a Staff-approved environmental specialist on site during construction activities that may affect sensitive areas. Sensitive areas may include, but are not limited to, wetlands and streams, and locations of threatened or endangered species. The environmental specialist shall be familiar with water quality protection issues and potential threatened or endangered species of plants and animals that may be encountered during project construction. The environmental specialist shall have authority to stop construction to assure that unforeseen environmental impacts do not progress and recommend procedures to resolve the impact. A map shall be provided to Staff showing sensitive areas which would be impacted during construction with information on when the environmental specialist would be present.
- (23) The Applicant shall contact Staff, the ODNR, and the USFWS within 24 hours if state or federal listed species are encountered during construction activities. Construction activities that could adversely impact the identified plants or animals shall be immediately halted until an appropriate course of action has been agreed upon by the Applicant, Staff and the appropriate agencies.
- (24) The Applicant shall avoid all impacts to perennial streams through facility design, HDD or other methods.
- (25) At least 60 days prior to the preconstruction conference, the Applicant shall submit a refined solar facility layout that shows the pipeline easement and right-of-way, the Applicant's setback of solar panels and inverters to that pipeline easement and right-of-way, the access roads necessary to avoid crossing the pipeline easement,

the location of the underground electric collection system within the pipeline easement, and the method for installing the underground electric collection system within the pipeline easement.

- (26) At least 60 days prior to the preconstruction conference, the Applicant shall submit a document indicating that it has met or addressed notable points from the pipeline owner's written guidelines for third party construction or maintenance activities within the pipeline's easement. Specific notable points include but are not limited to: obtained an encroachment agreement; insurance coverage; conducted an engineering study for crossing of pipelines with equipment; will use timber mats, bridges, or other protective material to cross the pipelines during construction; will meet or exceeded minimum HDD pipeline clearance of 60 inches from the pipelines; established non-interference with the pipelines' cathodic protection system; and will utilize proper shielding of the underground electric cable; will comply with setbacks for blasting near the pipeline, due to its compliance with Staff's recommended condition that it not utilize blasting for the project; and conducted a prior blast plan impact analysis.
- (27) The Applicant shall not utilize blasting to construct the solar facility.
- (28) The Applicant shall denote the pipeline easement on the final engineering drawings and install construction fence along the pipeline easement so that the pipeline easement is avoided during construction.
- (29) At least 30 days prior to the preconstruction conference, that the Applicant shall submit its emergency response plan to Staff for review and acceptance. That plan shall include a provision(s) to keep the Village of Quincy and Champaign County informed of the status of any spills, significant panel damage, and repair/clean-up/decommission schedule.
- (30) The Applicant shall construct the facility in a manner that incorporates post construction stormwater management under OHC00005 (Part III.G.2.e, pp. 19-27) in accordance with the Ohio Environmental Protection Agency's Guidance on Post-Construction Storm Water Controls for Solar Panel Arrays.
- (31) The Applicant shall take steps to prevent establishment and/or further propagation of noxious weeds identified in Ohio Adm.Code Chapter 901:5-37 during implementation of any pollinator-friendly plantings. Additionally, the Applicant will comply with any public orders concerning the abatement of noxious weeds.
- (32) Prior to commencement of construction activities that require transportation permits, the Applicant shall obtain all such permits. The Applicant shall coordinate with the appropriate authority regarding any temporary road closures, road use agreements, driveway permits, rights-of-way permits, lane closures, road access restrictions, and traffic control necessary for construction and operation of the proposed facility. Coordination shall include, but not be limited to, the county

engineer, the Ohio Department of Transportation, local law enforcement, and health and safety officials. The Applicant shall detail this coordination as part of a final transportation management plan which shall include a Road Use Maintenance Agreement entered by the Applicant with Champaign County. This plan will include subcontractors and decommissioning work and inspection. The plan shall be submitted to Staff prior to the preconstruction conference for review and confirmation by Staff that it complies with this condition.

- (33) At least 30 days prior to the preconstruction conference, the Applicant shall submit an updated decommissioning plan that includes: (1) a provision to monitor the site to ensure successful revegetation; (2) a provision calculating the decommissioning cost without regard to resale or salvage of the components and materials to be removed; and (3) rehabilitation of the project area and a provision where the performance bond for that decommissioning cost without regard to resale or salvage value is posted prior to the commencement of construction.

B. Exhibits

Subject to the terms and conditions of this Stipulation, the Applicant, the County Commissioners, the OFBF, and Staff agree, stipulate, and recommend that the following exhibits submitted to this docket be marked and admitted into the record of this proceeding:

1. Applicant Exhibit 1: Application filed on December 18, 2020.
2. Applicant Exhibit 2: Response to First Data Request filed on February 10, 2021.
3. Applicant Exhibit 3: Supplemental Response to First Data Request filed on February 16, 2021.
4. Applicant Exhibit 4: Second Supplemental Response to First Data Request filed on March 25, 2021.
5. Applicant Exhibit 5: Response to Second Data Request filed on April 15, 2021.
6. Applicant Exhibit 6: Response to Third Data Request filed on April 22, 2021.
7. Applicant Exhibit 7: Response to Fourth Data Request filed on May 3, 2021.
8. Applicant Exhibit 8: Response to Fifth Data Request filed on May 11, 2021.
9. Applicant Exhibit 9: Supplemental Response to Second and Fourth Data Requests filed on May 14, 2021.

10. Applicant Exhibit 10: Response to Sixth Data Request filed on May 17, 2021.
11. Applicant Exhibit 11: Second Supplemental Response to Fourth Data Request filed on May 20, 2021.
12. Applicant Exhibit 12: Third Supplemental Response to First Data Request filed on May 20, 2021.
13. Applicant Exhibit 13: Fourth Supplemental Response to First Data Request filed on August 17, 2019.
14. Applicant Exhibit 14: Certificate of Service of the October 6 and 8, 2020 Public Information Meetings, notice on property owners and entities filed on September 17, 2020, in accordance with Ohio Adm.Code 4906-3-03.
15. Applicant Exhibit 15: Proof of Publication of October 6 and 8, 2020 Public Information Meetings in the *Bellefontaine Examiner*, the *Urbana Daily Citizen*, and the *Sidney Daily News* filed on October 2, 2020, in accordance with Ohio Adm.Code 4906-3-03.
16. Applicant Exhibit 16: Certificate of Service of the accepted, complete application on local public officials and libraries filed on March 1, 2021, in accordance with Ohio Adm.Code 4906-3-07.
17. Applicant Exhibit 17: Proof of Service and Proof of Publication in the *Bellefontaine Examiner*, the *Urbana Daily Citizen*, and the *Sidney Daily News* of the procedural schedule, in accordance with the ALJ's March 15, 2021 Entry, filed on March 30, 2021.
18. Applicant Exhibit 18: Proof of Second Service and Proof of Second Publication in the *Bellefontaine Examiner*, the *Urbana Daily Citizen*, and the *Sidney Daily News* of the procedural schedule, in accordance with the ALJ's March 15, 2021 Entry, filed on June 2, 2021.
19. Applicant Exhibit 19: Second Proof of Service and Proof of Publication in the *Bellefontaine Examiner*, the *Urbana Daily Citizen*, and the *Sidney Daily News* of the second procedural schedule, in accordance with the ALJ's July 19, 2021 Entry, filed on August 17, 2021.
20. Joint Exhibit 1: The August 25, 2021 Stipulation signed on behalf of the Applicant, the County Commissioners, the OFBF, and Staff.

C. Other Terms of the Stipulation

1. This Stipulation is expressly conditioned upon its adoption by the Board without material modification. Each Signatory Party has the right, in its sole

discretion, to determine whether the Board's approval of this Stipulation constitutes a "material modification" thereof. If the Board rejects or materially modifies all of any part of this Stipulation, any Signatory Party shall have the right to apply for rehearing. If the Board does not adopt the Stipulation without material modification upon rehearing, or if the Board makes a material modification to any Order adopting the Stipulation pursuant to any reversal, vacation and/or remand by the Supreme Court of Ohio, then within 30 days of the Board's Entry on Rehearing or Order on Remand any Signatory Party may withdraw from the Stipulation by filing a notice with the Board ("Notice of Withdraw"). No Signatory Party shall file a Notice of Withdraw without first negotiating in good faith with the other Signatory Parties to achieve an outcome that substantially satisfies the intent of the Stipulation. If a new agreement achieves such an outcome, the Signatory Parties will file the new agreement for the Board's review and approval. If the discussions to achieve an outcome that substantially satisfies the intent of the Stipulation are unsuccessful, and a Signatory Party files a Notice of Withdrawal, then the Board will convene an evidentiary hearing to afford the Signatory Party the opportunity to contest the Stipulation by presenting evidence through witnesses, to cross examine witnesses, to present rebuttal testimony, and to brief all issues that the Board shall decide based upon the record and briefs. If the discussions to achieve an outcome that substantially satisfies the intent of the Stipulation are successful, then some or all of the Signatory Parties shall submit the amended Stipulation to the Board for approval after hearing if necessary.

2. The Signatory Parties agree and recognize that this Stipulation has been entered into only for the purpose of this proceeding.¹ Each party agrees not to assert against another party in any proceeding before the Board or any court, other than in a proceeding to enforce the terms of this Stipulation, that party's participation in this Stipulation as support for any particular position on any issue. Each party further agrees that this Stipulation carries no factual or legal precedent on any issue. The parties request that the Board recognize that its use of this Stipulation in any proceeding other than this proceeding is contrary to the intentions of the parties in entering into this Stipulation.

¹ The County Commissioners are signing this Stipulation for this Project only and based upon the facts in this proceeding, and the conditions agreed to herein. The County Commissioners' agreement in this case should not be construed as an indication of their view of other projects in Champaign County, each of which will be assessed by the County Commissioners individually in relation to the Champaign County Land Use Plan.

III. RECOMMENDED FINDINGS

The Signatory Parties agree that the record in this case, provided the Board approves the conditions in this Stipulation, contains sufficient probative evidence for the Board to find and determine, as findings of fact and conclusions of law, that:

A. Recommended Findings of Fact

1. The Applicant is a wholly-owned subsidiary of Open Road Renewables, LLC and Eolian LP (formerly named MAP Energy, LLC), and is licensed to do business in the state of Ohio.
2. The facility qualifies as a major utility facility as defined in R.C. 4906.01(B)(1).
3. On September 17, 2020, the Applicant filed a preapplication notification letter informing the Board of the public information meetings in this proceeding. Notice of the public information meetings was served on county and township officials and agencies, property owners, local first responders, the local school district, and the local libraries, and published in the *Bellefontaine Examiner*, the *Urbana Daily Citizen*, and the *Sidney Daily*. The public information meetings were held, as scheduled, on October 6 and 8, 2020.
4. The Applicant formally submitted its application for a Certificate of Environmental Compatibility and Public Need on December 18, 2020.
5. The County Commissioners and the OFBF were granted intervention on June 17, 2021.
6. On February 16, 2021, the Staff filed a letter stating that it had received sufficient information to begin its review of the Application as supplemented.
7. On March 4, 2021, the Applicant filed notice that the Application fee had been submitted.
8. On March 1, 2021, the Applicant filed a certificate of service indicating that a copy of the Application was served on local public officials and libraries.
9. On March 15, 2021, the ALJ established the procedural schedule and scheduled the local public and evidentiary hearings for June 8 and July 1, 2021, respectively.

10. On March 30 and June 2, 2021, the Applicant filed proof that the first and second notices of the procedural schedule were served and published in the *Bellefontaine Examiner, the Urbana Daily Citizen, and the Sidney Daily News*.
11. The Staff Report was filed on May 24, 2021.
12. The first public hearing was held on June 8, 2021.
13. On June 17, 2021, the ALJ directed that a second local public hearing should be held in this matter and suspended the remaining procedural schedule deadlines.
14. On July 19, 2021, the ALJ reestablished the procedural schedule in this matter and scheduled the second local public hearing and the commencement of the evidentiary hearing for August 19 and September 1, 2021, respectively.
15. On August 17, 2021, the Applicant filed proof that the notice of the reinstated procedural schedule was served and published in the *Bellefontaine Examiner, the Urbana Daily Citizen, and the Sidney Daily News*.
16. The second local public hearing was held on August 19, 2021.
17. On August 25, 2021, the Applicant, the County Commissioners, the OFBF, and Staff filed the Stipulation.
18. The adjudicatory hearing was called and continued on July 1, 2021. On September 1, 2021, the adjudicatory hearing will recommence.
19. The basis of need, as specified under R.C. 4906.10(A)(1), is not applicable to this generating facility project.
20. Adequate data on the project has been provided to determine the nature of the probable environmental impact, as required by R.C. 4906.10(A)(2).
21. Adequate data on the project has been provided to determine that the facility described in the application represents the minimum adverse environmental impact, considering the available technology and nature and economies of the various alternatives, and other pertinent considerations, as required by R.C. 4906.10(A)(3).

22. Adequate data on the project has been provided to determine that, because the project is an electric generation facility, the proposed electric generating facility is consistent with regional plans for expansion of the electric power grid of the electric systems serving the state of Ohio and interconnected utility systems, and that the facility will serve the interests of electric system economy and reliability, and the requirements of R.C. 4906.10(A)(4) are met.
23. Adequate data on the project has been provided to determine that, to the extent that any of them are applicable, the solar-powered generation facility will comply with the requirements in the R.C. regarding air and water pollution control, withdrawal of waters of the state, solid and hazardous waters, and air navigation, and all regulations thereunder, as required by R.C. 4906.10(A)(5).
24. Adequate data on the project has been provided to determine that the facility will serve the public interest, convenience, and necessity, as required by R.C. 4906.10(A)(6).
25. Adequate data on the project has been provided to determine what the facility's impact will be on the viability as agricultural land of any land in an existing agricultural district established under R.C. Chapter 929 that is located within the site of the proposed facility, as required by R.C. 4906.10(A)(7).
26. Adequate data on the project has been provided to determine that the facility as proposed incorporates maximum feasible water conservation practices considering available technology and the nature and economics of the various alternatives, as required by R.C. 4906.10(A)(8).
27. The record evidence in this matter provides sufficient factual data to enable the Board to make an informed decision.

B. Recommended Conclusions of Law

1. The Applicant is a "person" under R.C. 4906.01(A).
2. The proposed facility is a major utility facility as defined in R.C. 4906.01(B)(1).
3. The application complies with the requirements of Ohio Adm.Code Chapter 4906-3.
4. The requirement for the need for the facility under R.C. 4906.10(A)(1) is inapplicable.

5. The record establishes the nature of the probable environmental impact from construction, operation, and maintenance of the facility under R.C. 4906.10(A)(2).
6. The record establishes that the facility, if conditioned in the certificate as recommended by the Signatory Parties, represents the minimum adverse environmental impact, considering the state of available technology and the nature and economics of the various alternatives, and other pertinent considerations under R.C. 4906.10(A)(3).
7. The record establishes that the facility is consistent with regional plans for expansion of the electric power grid of the electric systems serving the state of Ohio and interconnected utility systems, and will serve the interests of electric system economy and reliability, as required by R.C. 4906.10(A)(4).
8. The record establishes, as required by R.C. 4906.10(A)(5), that, to the extent that any of them are applicable, construction of the proposed facility will comply with the requirements in the R.C. regarding air and water pollution control, withdrawal of waters of the state, solid and hazardous wastes, and air navigation, and all rules and standards adopted under the relevant Chapters of the R.C.
9. The record establishes that the facility, if conditioned in the certificate as recommended by the Signatory Parties, will serve the public interest, convenience, and necessity under R.C. 4906.10(A)(6).
10. The facility's impact on the viability as agricultural land of any land in an existing agricultural district has been determined under R.C. 4906.10(A)(7).
11. The record establishes that the facility would incorporate maximum feasible water conservation practices under R.C. 4906.10(A)(8).
12. Based on the record, the Signatory Parties recommend that the Board issue a Certificate of Environmental Compatibility and Public Need for construction, operation, and maintenance of the facility, which includes the conditions in the Staff Report, as presented and modified by this Stipulation.

The undersigned hereby stipulate and agree and they represent that they are authorized to enter into this Joint Stipulation and Recommendation.

Respectfully submitted on behalf of,

THE STAFF OF THE OHIO POWER SITING BOARD CLEARVIEW SOLAR I, LLC

By: /s/ Jodi Bair per email 8/25/21 CMTP
Jodi Bair
Kyle Kern
Assistant Attorneys General
Public Utilities Section
OFFICE OF THE ATTORNEY GENERAL
30 East Broad Street, 16th Floor
Columbus, Ohio 43215

By: /s/ Christine M.T. Pirik
Christine M.T. Pirik
(Counsel of Record)
Matthew McDonnell
DICKINSON WRIGHT PLLC
150 East Gay Street, Suite 2400
Columbus, Ohio 43215

THE OHIO FARM BUREAU FEDERATION

By: /s/ Amy M. Milam per email 8/25/21 CMTP
Chad A. Endsley
Chief Legal Counsel
Amy M. Milam
Leah F. Curtis
Ohio Farm Bureau Federation
280 North High Street
P.O. Box 182383
Columbus, Ohio 43218

**KEVIN S. TALEBI
CHAMPAIGN COUNTY
PROSECUTING ATTORNEY**

By: _____
Jane A. Napier
Assistant Prosecuting Attorney
200 North Main Street
Urbana, Ohio 43078

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

8/25/2021 3:42:09 PM

in

Case No(s). 20-1362-EL-BGN

Summary: Stipulation - Joint Stipulation and Recommendation electronically filed by Christine M.T. Pirik on behalf of Clearview Solar I, LLC