

January 21, 2022

Ms. Tanowa Troupe, Secretary
Docketing Division, Ohio Power Siting Board
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Ms. Troupe:

In accordance with Ohio Administrative Code (“OAC”) Rule 4906-2-04(A)(3) and OAC Chapter 4906-6, American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, transmits the enclosed Letter of Notification application (“LON”), which was completed in accordance with the requirements of OAC Chapter 4906-06.

In this Project, ATSI is proposing to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new, embedded single-pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

Pursuant to OAC Rule 4906-2-04(A)(3), please be advised of the following:

a) Name and address of the applicants:

American Transmission Systems, Incorporated
76 South Main Street
Akron, Ohio 44308

b) Name and location of proposed facilities:

London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project. The Project is located in Jerome Township, Union County, Ohio.

c) Applicant's representative:

Nataliya Bryksenkova, Engineer
Transmission Siting
FirstEnergy Service Company
76 South Main Street
Akron, OH 44308-1890

d) The Project Description that was provided in the pre-application notification letter required by OAC 4906-6-03 has not been amended or changed in the attached Letter of Notification Application.

e) A notarized statement that the information contained in the application is complete and accurate is provided as Attachment 1.

We have provided a copy of the LON to each official of the political subdivisions immediately affected by the proposed Project listed in Attachment 2. Copies of the transmittal letters addressed to the local government representatives of Jerome Township, Union County, Ohio are enclosed for your file. These materials are being provided as proof of compliance with OAC Rule 4906-6-07. An exemplar of the informational letter sent to property owners is attached as Attachment 3. This is being provided as proof of compliance with OAC Rule 4906-6-08(B).

Should staff of the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330)761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachments

**London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case Number 22-0007-EL-BLN**

Date: January 21, 2022

**Attachment 1
Acknowledgement of Nataliya Bryksenkova**

**London-Tangy 138kV Tap to Mitchell LON Acknowledgment E-Notary.docx**

DocVerify ID: 65FF5319-C598-4644-8680-B5D2E4400C40
Created: January 21, 2022 04:40:38 -8:00
Pages: 1
Remote Notary: Yes / State: OH

This document is a DocVerify VeriVaulted protected version of the document named above. It was created by a notary or on the behalf of a notary, and it is also a DocVerify E-Sign document, which means this document was created for the purposes of Electronic Signatures and/or Electronic Notary. Tampered or altered documents can be easily verified and validated with the DocVerify veriCheck system. This remote online notarization involved the use of communication technology.

Go to www.docverify.com at any time to verify or validate the authenticity and integrity of this or any other DocVerify VeriVaulted document.

E-Signature Summary**E-Signature 1: Nataliya Bryksenkova (NB)**

January 21, 2022 04:51:43 -8:00 [4EF1C08E1B55] [98.27.152.234]
nbryksenkova@firstenergycorp.com (Principal) (Personally Known)

E-Signature Notary: Matthew J. Albright (MJA)

January 21, 2022 04:51:43 -8:00 [CAB61C26378E] [173.89.93.65]
malbright@firstenergycorp.com
I, Matthew J. Albright, did witness the participants named above
electronically sign this document.



BEFORE THE
OHIO POWER SITING BOARD

In The Matter Of:)
The Application of American)
Transmission Systems, Incorporated for a)
Certificate of Environmental)
Compatibility and Public Need for the)
Construction for the London-Tangy 138)
kV Transmission Line Tap to Mitchell)
Delivery Point Substation Project)

Case No. 22-0007-EL-BLN

ACKNOWLEDGEMENT OF NATALIYA BRYKSENKOVA

I, Nataliya Bryksenкова, state the following:

Pursuant to Ohio Administrative Code Rule 4906-2-04(A)(3)(e), I am the authorized representative of the Applicant in this case, and I affirm that the Letter of Notification application filed in this matter is true and accurate to the best of my information and belief.

Nataliya Bryksenкова

Signed on 2022/01/21 04:51:43 -8:00

Nataliya Bryksenкова
FirstEnergy Service Company

State of Ohio)
County of Summit) ss:

The foregoing instrument was acknowledged before me this 21st day of January 2022.

Matthew J Albright

Signed on 2022/01/21 04:51:43 -8:00

Notary Public



Attachment 2
Officials Served Copy of Letter of Notification
London-Tangy 138 kV Transmission Line Tap
to Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Union County

Ms. Christiane Schmenk,
President
Union County Commissioner
233 West Sixth Street
Marysville, OH 43040

Mr. Steve Robinson,
Vice President
Union County Commissioner
233 West Sixth Street
Marysville, OH 43040

Mr. Dave Burke,
Union County Commissioner
233 West Sixth Street
Marysville, OH 43040

Mr. Tim Hansley,
Union County Administrator
233 West Sixth Street
Marysville, OH 43040

Mr. Eric Phillips,
Executive Director
Union County
Economic Development
227 East Fifth Street
Marysville, OH 43040

Mr. Jeff Stauch, P.E., P.S.
Union County Engineer
233 West Sixth Street
Marysville, OH 43040

Jerome Township

Mr. Joe Craft, Trustee
Jerome Township
8770 Brock Road
Plain City, OH 43064

Mr. CJ Lovejoy, Trustee
Jerome Township
8495 SR 736
Plain City, OH 43064

Ms. Megan Sloat, Trustee
Jerome Township
10251 Mitchell Dewitt Road
Plain City, OH 43064

Mr. Robert Caldwell, Fiscal Officer
Jerome Township
8770 Brock Road
Plain City, OH 43064

Library

Ms. Chris Long, Library Director
Plain City Public Library
305 West Main Street
Plain City, Ohio 43064

January 21, 2022

Ms. Christiane Schmenk, President
Union County Commissioner
233 West Sixth Street
Marysville, OH 43040

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Commissioner Schmenk,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. Steve Robinson, Vice President
Union County Commissioner
233 West Sixth Street
Marysville, OH 43040

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Commissioner Robinson,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. Dave Burke,
Union County Commissioner
233 West Sixth Street
Marysville, OH 43040

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Commissioner Burke,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. Tim Hansley,
Union County Administrator
233 West Sixth Street
Marysville, OH 43040

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Mr. Hansley,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. Eric Phillips, Executive Director
Union County Economic Development
227 East Fifth Street
Marysville, OH 43040

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Project
Case No. 22-0007-EL-BLN

Dear Mr. Phillips,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. Jeff Stauch, P.E., P.S.
Union County Engineer
233 West Sixth Street
Marysville, OH 43040

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Mr. Stauch,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. Joe Craft, Trustee
Jerome Township
8770 Brock Road
Plain City, OH 43064

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Mr. Craft,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. CJ Lovejoy, Trustee
Jerome Township
8495 SR 736
Plain City, OH 43064

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Mr. Lovejoy,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Ms. Megan Sloat, Trustee
Jerome Township
10251 Mitchell Dewitt Road
Plain City, OH 43064

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Ms. Sloat,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Mr. Robert Caldwell, Fiscal Officer
Jerome Township
8770 Brock Road
Plain City, OH 43064

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Mr. Caldwell,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed a Letter of Notification Application (“LON”) with the Ohio Power Siting Board (“OPSB”) seeking a Certificate of Environmental Compatibility and Public Need to construct the London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation Project (“Project”). ATSI proposes to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new embedded single pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for an LON. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the enclosed LON with the OPSB for their review and approval. The LON contains a more detailed description of the Project and is provided for your information.

If there are any questions concerning this matter, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment

January 21, 2022

Ms. Chris Long, Library Director
Plain City Public Library
305 West Main Street
Plain City, Ohio 43064

Letter of Notification
London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Dear Ms. Long,

Enclosed please find one copy of the Letter of Notification application (“LON”) of American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, for the London-Tangy 138 kV Tap to Mitchell Delivery Point Substation Project (“Project”) that has been filed with the Ohio Power Siting Board (“OPSB”).

We are providing a copy of the Letter of Notification application for placement in your library pursuant to the requirements of Ohio Administrative Code (“OAC”) Rule 4906-6-07(A)(2), which requires ATSI to place a copy of the LON in the main public libraries of the political subdivisions in which any portion of the Project is to be located. Please therefore make the Letter of Notification application available for public reference in the Plain City Public Library.

As described in the LON, ATSI is seeking approval from the OPSB to extend a tap from the existing London-Tangy 138 kV Transmission Line approximately 400 feet (0.08 mile) to a new substation for the Union Rural Electric Cooperative (“UREC”), which will be known as the Mitchell Delivery Point Substation. The transmission line tap will require removal of one (1) structure and installation of four (4) new, embedded single-pole wood structures consisting of one (1) tap structure and three (3) switch structures. The Project is in Jerome Township, Union County, Ohio.

Please feel free to call me with any question you have relative to making the Letter of Notification application readily available to your patrons. My phone number is 330-761-4473.

Sincerely,



Nataliya Bryksenkova,
Engineer
Transmission Siting
FirstEnergy Service Company

Attachment 3
Property Owners Served Notice Letters of the Letter of Notification
London-Tangy 138 kV Transmission Line Tap
to Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN

Parcel Number	Easement Status
1500200100010	Previously Obtained
1500260010020	Will be Obtained

January 21, 2022

Property Owner
Address
City, State Zip

Re: Parcel(s): #####

**London-Tangy 138 kV Transmission Line Tap to
Mitchell Delivery Point Substation Project
Case No. 22-0007-EL-BLN**

Dear Property Owner:

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, is seeking approval from the Ohio Power Siting Board (“OPSB”) to construct and maintain a 400 feet (0.08 mile) long tap to serve a new customer, Union Rural Electric Cooperative (“UREC”), from the London-Tangy 138kV Transmission Line. The proposed transmission line tap will connect the London-Tangy 138 kV Transmission Line to UREC’s Mitchell Delivery Point Substation (“Project”). The Project is located in Jerome Township, Union County, Ohio.

In accordance with Appendix A to Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for a Letter of Notification application (“LON”). Therefore, this letter is being sent to you in compliance with OAC Rule 4906-6-08(A) to provide you with notice that ATSI has prepared and filed an LON to construct, operate, and maintain the Project that is now pending before the Board in Case No. 22-0007-EL-BLN.

The LON contains a more detailed description of the Project and can be reviewed at the Plain City Public Library, 305 West Main Street, Plain City, Ohio 43064.

A copy of the LON is also available for public inspection at the offices of the Ohio Power Siting Board, c/o Public Utilities Commission of Ohio, Utilities Department, 12th Floor, Borden Building, 180 East Broad Street, Columbus, Ohio 43215-3793, or on the website of the Board: www.opsb.ohio.gov. The OPSB can also be reached via email at: contactOPSB@puc.state.oh.us.

Finally, a copy of the LON will be posted on FirstEnergy’s website at www.firstenergycorp.com/about/transmission_project/ohio.html along with information on how to request a hard copy of the application, if you wish to order one.

In accordance with OAC Rule 4906-6-08(A)(6), please be advised that interested persons may file motions to intervene and/or file comments with the OPSB within ten days of the date of the publication of the public notice of the filing of this Project with the OPSB, in accordance with

OAC Rule 4906-2-12, or later if good cause is shown. Petitions to intervene and comments should be addressed to the Ohio Power Siting Board, 180 East Broad Street, Columbus, Ohio 43215-3793 and reference Case No. 22-0007-EL-BLN.

If you have any questions concerning the Project, I will be happy to answer them. You can contact me at the transmission projects hotline number 1-888-311-4737 or by email at transmissionprojects@firstenergycorp.com. The Project name, London-Tangy 138 kV Transmission Line Tap to Mitchell Delivery Point Substation, and Case Number (22-0007-EL-BLN) should be referenced in all communications.

Sincerely,



Nataliya Bryksenkova,
Engineer
Transmission Siting
FirstEnergy Service Company

**This foregoing document was electronically filed with the Public Utilities
Commission of Ohio Docketing Information System on**

1/21/2022 3:38:57 PM

in

Case No(s). 22-0007-EL-BLN

Summary: Application Letter of Notification Application (Part 1) electronically filed
by Ms. Devan K. Flahive on behalf of American Transmission Systems
Incorporated