
AES Ohio
1900 Dryden Road
Dayton, Ohio 45439

January 28, 2021

Chairman Jenifer French
Ohio Power Siting Board
180 East Broad Street
Columbus, Ohio 43215

Re: **West Milton – Eldean 138kV Line**
Ohio Power Siting Board Case No. 18-1259-EL-BTX
Notification of Miami County Temporary Driveway Permit

Dear Chairman French,

The Dayton Power and Light Company (“DP&L”) doing business as AES Ohio submits this notice to inform you of the following agency approval to satisfy Conditions 9 and 19 related to the January 15, 2020 Ohio Power Siting Board (“OPSB”) approval of the above referenced project. On January 25, 2022, the Miami County Engineer’s Office approved the abovementioned project to install temporary driveways along various county and township roads, as specified in the permit (Enclosure).

Additional permits to satisfy Conditions 9 and 19 are forthcoming, and AES Ohio will submit those permits once obtained.

Please feel free to contact me if you have any questions regarding this notification letter.

Respectfully submitted,

ss:/ *Randall V. Griffin*

Randall V Griffin (Ohio Bar No. 0080499)
Chief Regulatory Counsel
AES Ohio
937-479-8983 (cell)
Randall.griffin@aes.com

Enclosure: Miami County Engineer’s Office Temporary Driveway Permit

Enclosure
Miami County Engineer's Office Temporary Driveway Permit



Paul P. Huelskamp, PE, PS
Miami County Engineer

APPLICATION FOR DRIVEWAY AND/OR DITCH ENCLOSURE PERMIT

OFFICE OF THE MIAMI COUNTY ENGINEER
2100 N. County Road 25-A, Troy, Ohio 45373
Telephone: (937) 440-5656 Fax: (937) 440-5659
mail: MCEO@MiamiCountyOhio.gov

ORC 5543.16: "The owners of land shall construct and keep in repair all approaches or driveways from the public roads, under the direction of the County Engineer."

The applicant does hereby make application to install:

- | | |
|--|---|
| <input type="checkbox"/> Residential Drive | <input type="checkbox"/> All Purpose Farm Residence Drive |
| <input type="checkbox"/> Field Entrance for farm equipment | <input type="checkbox"/> Ditch Enclosure |
| <input type="checkbox"/> Commercial Drive | |

LOCATION: Township: Various Sec.: Various Town: Various Range: Various
Road Name: Various roads. (See AES plans)

DETAILS: AES transmission line installation along various County and Township Roads.
(See attached plans)

Is there already an address assigned for this location? ☐ Yes ☒ No
If yes, what is it? _____
If no, your new address is: Temporary construction entrances only.

The Property Owner does agree to the following conditions:

1. During the progress of the work, such barriers shall be maintained as may be necessary for the protection of the traveling public.
2. Traffic shall be maintained.
3. The permit holder shall be responsible for all damages to persons or property due to or resulting from any work performed under this permit.
4. The berm of the existing road in the driveway area shall be excavated to a minimum of 6 inches to provide satisfactory granular base material. If a concrete drive is to be installed on a County road, the concrete shall be terminated three feet from the edge of pavement.
5. Pipe or conduit shall be installed to the grade line of ditch.
6. If any grading or construction performed under this permit interferes with the drainage of the highway in any way, it shall be the responsibility of the permit holder to correct same to the satisfaction of the County Engineer.
7. It is agreed that the maintenance and repair of the above installation shall be the responsibility of the property owner and shall be maintained so that the drainage of the road shall not be impaired.

ENGINEER'S COMMENTS: See AES Temporary Drive Permits General Conditions

Property owners name: (See attached plans)

Applicant's name: AES Ohio Date: 1/25/2022

Address: 1900 Dryden Road

Dayton, OH 45439

Telephone: 937-331-4032

Application approved by: _____ Date: _____

For Paul P. Huelskamp, PE, PS, Miami County Engineer

This permit is valid for 12 months from date of approval and is non-transferable to other parties.

Miami County Engineer's Office

Instructions for APPLICATION and INSTALLATION of DRIVEWAYS

1. Applicant shall place a stake at the centerline of the proposed driveway, approximately 10' off of the edge of the pavement, prior to site inspection.
2. This office will inspect the site and determine the size of the culvert needed, if any. This permit will then be mailed to the address and person listed on the front of this permit. If a pipe is required, the pipe will be installed per the requirements of this office. This office will also provide advice on the installation.
3. It shall then be the responsibility of the property owner or his agent to install the pipe at the grade and location as established by this permit and this office. If the County Engineer anticipates a setback of the existing ditch line, it shall be the responsibility of the applicant to grade from the existing side ditch to the new culvert.
4. If a concrete drive is to be installed on a county road, the concrete shall terminate three feet from the edge of the pavement. After the concrete is in place, the applicant shall notify this office and asphaltic concrete will be placed by County crews in the approach between the road and the drive. This office also handles driveway permits on township roads but does not build approaches on township roads. If your driveway is on a township road, you need to contact your township trustees to see how and if they provide this service.
5. When the driveway is completed, you should call the County Engineer's Office for final inspection.
6. Mail box supports shall not be larger than 4" x 4" timber or 2½" standard wall steel pipe. Other supports having a cross section of equal or less breakaway characteristics may be used with permission of the County Engineer.
7. Prior to commencement of any work (including, but not limited to, driveway construction), the applicant and/or property owner shall contact the Miami County Planning and Zoning Office to determine if a FEMA Flood Plain Permit is required.

AES Ohio Temporary Drive Permits General Conditions:

1. Drive pipes shall be either reinforced concrete or corrugated metal with a minimum diameter of 12 inches and have a minimum length of 24 feet.
2. No Temporary driveway shall remain in place following the completion of the transmission line construction without permission of the Miami County Engineer's Office.
3. All temporary driveway locations shall be removed and ditch flow line restored and all the disturbed areas graded, seeded and mulched to the satisfaction of the Miami County Engineer.
4. Any damage to the pavement due to construction traffic utilizing the drive entrance shall be repaired by the permit holder.
5. In the event a temporary driveway causes flooding or in any way impedes the public use of the highway, Miami County reserves the right to require a pipe to be installed or remove the driveway or make repairs and charge the permit holder.

Type	Construction Entrance Number	Latitude	Longitude	Section Number	Township/Range	Township Name	PARCELID	Location Street Name	Deeded Owner	NOTES
New Construction Entrance	CE2	40.0824	-84.24103	7	T 5 N R 6 E	CONCORD	C06059900	EXPERIMENT FARM	OWNER NOT LISTED	12" Pipe Needed
Upgrade Existing Entrance	CE3	40.08356	-84.26033	6	T 5 N R 6 E	CONCORD	C06033320	WASHINGTON	THIES RICHARD P & DEBRA L	No Pipe
New Construction Entrance	CE4	40.08338	-84.2605	1	T 7 N R 5 E	CONCORD	C06034010	WASHINGTON	EMARI AN OHIO LIMITED FAMILY PARTNERSHIP	12" Pipe Needed
New Construction Entrance	CE5	40.08263	-84.26044	1	T 7 N R 5 E	CONCORD	C06034010	WASHINGTON	EMARI AN OHIO LIMITED FAMILY PARTNERSHIP	12" Pipe Needed Adjacent 12" Drive Pipe
New Construction Entrance	CE6	40.07575	-84.2697	12	T 7 N R 5 E	CONCORD	C06034710	ELDEAN	WATERWHEEL FARM INC	No Pipe
New Construction Entrance	CE7	40.07564	-84.27431	12	T 7 N R 5 E	CONCORD	C06034610	ELDEAN	THIES RICHARD P & DEBRA L	No Pipe
New Construction Entrance	CE8	40.07553	-84.27427	12	T 7 N R 5 E	CONCORD	C06034800	ELDEAN	JACKSON RONALD D (TOD)	12" Pipe Needed
New Construction Entrance	CE13	40.0636	-84.28794	14	T 7 N R 5 E	CONCORD	C06004400	FOREST HILL	MYERS TOM C & ALICE C	No Pipe
New Construction Entrance	CE14	40.06236	-84.28785	14	T 7 N R 5 E	CONCORD	C06004200	FOREST HILL	CAREY & CAREY LLC	No Pipe
New Construction Entrance	CE15	40.06093	-84.28781	14	T 7 N R 5 E	CONCORD	C06004200	FOREST HILL	CAREY & CAREY LLC	No Pipe
New Construction Entrance	CE16	40.0599	-84.28773	14	T 7 N R 5 E	CONCORD	C06003900	MCCURDY	CAREY & CAREY LLC	No Pipe

Type	Construction Entrance Number	Latitude	Longitude	Section Number	Township/Range	Township Name	PARCELID	Location Street Name	Deeded Owner	NOTES
New Construction Entrance	CE17	40.05884	-84.28777	14	T 7 N R 5 E	CONCORD	C06003900	FOREST HILL	CAREY & CAREY LLC	No Pipe
New Construction Entrance	CE21	40.03869	-84.2872	23	T 7 N R 5 E	CONCORD	C06005550	FOREST HILL	JACKSON SUE A TRUSTEE	12" Pipe Needed
New Construction Entrance	CE24	40.03071	-84.28717	26	T 7 N R 5 E	CONCORD	C06006900	FOREST HILL	EDMISTON DEBORAH L TRUSTEE	12" Pipe Needed
New Construction Entrance	CE25	40.02606	-84.28704	26	T 7 N R 5 E	CONCORD	C06006900	FOREST HILL	EDMISTON DEBORAH L TRUSTEE	12" Pipe Needed
New Construction Entrance	CE26	40.02364	-84.28704	26	T 7 N R 5 E	CONCORD	C06006900	FENNER	EDMISTON DEBORAH L TRUSTEE	36" Pipe Needed
New Construction Entrance	CE27	40.02352	-84.28703	35	T 7 N R 5 E	CONCORD	C06007400	FENNER	MOORE KEVIN S TRUSTEE & ALISSA L TRUSTEE	36" Pipe Needed
New Construction Entrance	CE28	40.00957	-84.28665	35	T 7 N R 5 E	CONCORD	C06007900	FOREST HILL	MOORE KEVIN S TRUSTEE & ALISSA L TRUSTEE	No Pipe
New Construction Entrance	CE29	40.008933	-84.286774	2	T 6 N R 5 E	UNION	L35000010	HORSESHOE BEND	BRINKMAN RICHARD L & REBECCA E	12" Pipe Needed
New Construction Entrance	CE30	40.008805	-84.290664	2	T 6 N R 5 E	UNION	L35000001	Harter	BRINKMAN RICHARD L & REBECCA E	No Pipe
New Construction Entrance	CE31	40.003097	-84.290566	2	T 6 N R 5 E	UNION	L35000001	Harter	BRINKMAN RICHARD L & REBECCA E	No Pipe
New Construction Entrance	CE33	40.000690	-84.295286	2	T 6 N R 5 E	UNION	L32025400	KESSLER	EARLS LOUIS H JR	No Pipe

Type	Construction Entrance Number	Latitude	Longitude	Section Number	Township/Range	Township Name	PARCELID	Location Street Name	Deeded Owner	NOTES
New Construction Entrance	CE36	39.998091	-84.304706	3	T 6 N R 5 E	UNION	L32024950	GREENLEE	JOHNS CHARLES W JR & LORA B	No Pipe
Upgrade Existing Entrance	CE39	39.994496	-84.314502	4	T 6 N R 5 E	UNION	L32026950	KESSLER-FREDERICK	WALLS CECIL W & NORMA J	No Pipe
New Construction Entrance	CE47	39.986046	-84.351841	7	T 6 N R 5 E	UNION	L32054500	DAVIS	HOOVER JOHN E TRUSTEE & ROSALIE TRUSTEE	Pipe Needed
New Construction Entrance	CE48	39.979064	-84.351658	7	T 6 N R 5 E	UNION	L32054710	MARKLEY	BRIDENBAUGH DWAIN H & BERNADENE A (TOD)	12" Pipe Needed
New Construction Entrance	CE49	39.978938	-84.351663	18	T 6 N R 5 E	UNION	L32066850	MARKLEY	VAN KIRK JAMES M & SHERRY E ROSS	12" Pipe Needed
New Construction Entrance	CE50	39.977506	-84.351624	18	T 6 N R 5 E	UNION	L32066850	DAVIS	VAN KIRK JAMES M & SHERRY E ROSS	12" Pipe Needed
New Construction Entrance	CE51	39.974265	-84.351567	18	T 6 N R 5 E	UNION	L32066800	DAVIS	FURLONG C KENT (TOD) & MARY BETH (TOD)	12" Pipe Needed
New Construction Entrance	CE52	39.972895	-84.351407	17	T 6 N R 5 E	UNION	L32064400	DAVIS	FURLONG C KENT (TOD) & MARY BETH (TOD)	No Pipe
New Construction Entrance	CE53	39.967512	-84.351375	17	T 6 N R 5 E	UNION	L32064400	DAVIS	FURLONG C KENT (TOD) & MARY BETH (TOD)	12" Pipe Needed
New Construction Entrance	CE55	39.962249	-84.351303	20	T 6 N R 5 E	UNION	L39250202	DAVIS	MILTON-UNION EXEMPTED VILLAGE SCHOOLS	12" Pipe Needed
Upgrade Existing Entrance	CE56	39.956700	-84.351149	20	T 6 N R 5 E	UNION	L32060700	DAVIS	BROWN KENT A (TR) & MADILYN K (TR)	12" Pipe Needed

Type	Construction Entrance Number	Latitude	Longitude	Section Number	Township/Range	Township Name	PARCELID	Location Street Name	Deeded Owner	NOTES
New Construction Entrance	CE57	39.953129	-84.337200	20	T 6 N R 5 E	UNION	L32061300	JAY	THE VORE FAMILY FARMS LLC	12" Pipe Needed
Upgrade Existing Entrance	CE58	39.953051	-84.337095	20	T 6 N R 5 E	UNION	L32061200	JAY	LONG WILLA L (LE) & @(3)	12" Pipe Needed
New Construction Entrance	CE59	39.951565	-84.331889	21	T 6 N R 5 E	UNION	L32061200	LOWRY	LONG WILLA L (LE) & @(3)	No Pipe
New Construction Entrance	CE60	39.945684	-84.331745	28	T 6 N R 5 E	UNION	L32043970	EMERICK	DAUM CLARA J TRUSTEE & ALFRED E TRUSTEE	12" Pipe Needed
New Construction Entrance	CE61	39.945555	-84.331913	29	T 6 N R 5 E	UNION	L32043910	EMERICK	SPARKS JOEY D & KRISTEN M	12" Pipe Needed

**This foregoing document was electronically filed with the Public Utilities
Commission of Ohio Docketing Information System on**

1/28/2022 5:25:35 PM

in

Case No(s). 18-1259-EL-BTX

Summary: Notification of Miami County Temporary Driveway Permit for West Milton
- Eldean 138kV Line electronically filed by Ms. Sarah Howdeshelt on behalf of The
Dayton Power and Light Company