

---

AES Ohio  
1900 Dryden Road  
Dayton, Ohio 45439

February 8, 2021

Chairman Jenifer French  
Ohio Power Siting Board  
180 East Broad Street  
Columbus, Ohio 43215

Re: **West Milton – Eldean 138kV Line**  
Ohio Power Siting Board Case No. 18-1259-EL-BTX  
Notification of Miami County ROW Permits

Dear Chairman French,

The Dayton Power and Light Company doing business as “AES Ohio” submits this notice to inform you of the permits obtained to satisfy Condition 9 related to the January 15, 2020 Ohio Power Siting Board (“OPSB”) approval of the above referenced project. On January 28, 2022, the Miami County Engineer’s Office determined that the above referenced project has been approved to work within county and township road right-of-way (ROW) limits, as specified in the permits (Enclosure).

Please feel free to contact me if you have any questions regarding this notification letter.

Respectfully submitted,

ss:/ *Randall V. Griffin*

Randall V Griffin (Ohio Bar No. 0080499)  
Chief Regulatory Counsel  
AES Ohio  
937-479-8983 (cell)  
[Randall.griffin@aes.com](mailto:Randall.griffin@aes.com)

Enclosure: Miami County ROW Permits

---

**Enclosure**  
**Miami County ROW Permits**



Paul P. Huelskamp, PE, PS  
Miami County Engineer

APPLICATION FOR PERMIT TO WORK WITHIN  
COUNTY/TOWNSHIP ROAD RIGHT-OF-WAY LIMITS  
OFFICE OF THE MIAMI COUNTY ENGINEER  
2100 N. County Road 25-A, Troy, Ohio 45373  
Telephone: (937) 440-5656 Fax: (937) 440-5659  
E-mail: [MCEO@MiamiCountyOhio.gov](mailto:MCEO@MiamiCountyOhio.gov)

APPLICANT NAME: AES Ohio DATE: 1/28/2022

ADDRESS: 1900 Dryden Road  
Dayton, OH 45439

TELEPHONE: 937-331-4032

PROJECT LOCATION: Road Name Forest Hill Road Township Concord

Address or description of location: Starting at intersection with Thomas Road (40.063593, -84.287961),  
ending at intersection with Horseshoe Bend Road (40.009137, -84.286587)

TYPE OF INSTALLATION: Underground Overhead Steel Pole Electric Transmission Line Structures

INSTALLATION METHOD:

- ☐ Open cut road crossing ☒ Work adjacent to roadway - within R/W limits  
☐ Boring or tunneling roadway ☐ Other describe under "SPECIAL CONDITIONS"

DESCRIPTION OF WORK:

Trench width n/a Type utility or service Electric Transmission  
Depth of installation 20 feet maximum Type material installing Steel poles with gravel backfill or concrete foundations  
Type structures involved 78 poles Amount/Quantity of work 3.75 miles within road ROW (ft./units)

PROJECT DURATION: Starting date: approx. 2/1/2022 Completion date: approx. 12/31/2022 (restoration)

PERMIT VALID FOR 365 DAYS. After indicated time period permit must be submitted for renewal or extension.

SPECIAL CONDITIONS, comments, or additional information:

Permit application for construction crews to install new transmission line pole structures from County Road shoulder. Traffic flow will be maintained down to  
one lane along county road where crews are working. Traffic control plan will be implemented with flaggers and warning signs.

Miami County Engineer's Office will be notified when work within County Road ROW is to be taking place.

I/We hereby agree to all terms, conditions, and restrictions as stated and apply to the work to be done under this permit. All future responsibilities must be assumed by the applicant, his grantee, successors, and assignees.

SIGNED: Andrew Schieltz Title: Transmission Engineer

Firm: AES Ohio Date: 1/28/2022

PERMIT TO PERFORM WORK AS STATED ON THIS APPLICATION IS HEREBY GRANTED.

Paul P. Huelskamp Date: 1/28/2022  
Paul P. Huelskamp, PE, PS County Engineer

\* Please submit one (1) set of plans for proposed project with this Application.

TOWNSHIP TRUSTEES NOTIFICATION: Date: \_\_\_\_\_ ☐ Approval ☐ Disapproval

Comments: \_\_\_\_\_

\*This application, when signed by the Miami County Engineer, shall serve as a permit as authorized by the Board of Miami County Commissioner's Resolution No. 22-01-38.

\*This permit is also subject to the terms and conditions as listed on page two of this permit.



Paul P. Huelskamp, PE, PS  
Miami County Engineer

APPLICATION FOR PERMIT TO WORK WITHIN  
COUNTY/TOWNSHIP ROAD RIGHT-OF-WAY LIMITS  
OFFICE OF THE MIAMI COUNTY ENGINEER  
2100 N. County Road 25-A, Troy, Ohio 45373  
Telephone: (937) 440-5656 Fax: (937) 440-5659  
E-mail: [MCEO@MiamiCountyOhio.gov](mailto:MCEO@MiamiCountyOhio.gov)

APPLICANT NAME: AES Ohio DATE: 1/28/2022

ADDRESS: 1900 Dryden Road  
Dayton, OH 45439

TELEPHONE: 937-331-4032

PROJECT LOCATION: Road Name Horseshoe Bend Road Township Union

Address or description of location: Starting at intersection with Forest Hill Road (40.009002, -84.286789),  
ending at intersection with Harter Road (40.008937, -84.290693)

TYPE OF INSTALLATION: Underground Overhead Steel Pole Electric Transmission Line Structures

INSTALLATION METHOD:

- ☐ Open cut road crossing ☒ Work adjacent to roadway - within R/W limits  
☐ Boring or tunneling roadway ☐ Other describe under "SPECIAL CONDITIONS"

DESCRIPTION OF WORK:

Trench width n/a Type utility or service Electric Transmission  
Depth of installation 20 feet maximum Type material installing Steel poles with gravel backfill or concrete foundations  
Type structures involved 4 poles Amount/Quantity of work 0.25 miles within road ROW (ft./units)

PROJECT DURATION: Starting date: approx. 2/1/2022 Completion date: approx. 12/31/2022 (restoration)

PERMIT VALID FOR 365 DAYS. After indicated time period permit must be submitted for renewal or extension.

SPECIAL CONDITIONS, comments, or additional information:

Permit application for construction crews to install new transmission line pole structures from County Road shoulder. Traffic flow will be maintained down to one lane along county road where crews are working. Traffic control plan will be implemented with flaggers and warning signs.  
Miami County Engineer's Office will be notified when work within County Road ROW is to be taking place.

I/We hereby agree to all terms, conditions, and restrictions as stated and apply to the work to be done under this permit. All future responsibilities must be assumed by the applicant, his grantee, successors, and assignees.

SIGNED: Andrew Schieltz Title: Transmission Engineer

Firm: AES Ohio Date: 1/28/2022

PERMIT TO PERFORM WORK AS STATED ON THIS APPLICATION IS HEREBY GRANTED.

Paul P. Huelskamp Date: 1/28/2022  
Paul P. Huelskamp, PE, PS County Engineer

\* Please submit one (1) set of plans for proposed project with this Application.

TOWNSHIP TRUSTEES NOTIFICATION: Date: \_\_\_\_\_ ☐ Approval ☐ Disapproval

Comments: \_\_\_\_\_

\*This application, when signed by the Miami County Engineer, shall serve as a permit as authorized by the Board of Miami County Commissioner's Resolution No. 22-01-38.

\*This permit is also subject to the terms and conditions as listed on page two of this permit.





APPLICATION FOR PERMIT TO WORK WITHIN  
COUNTY/TOWNSHIP ROAD RIGHT-OF-WAY LIMITS  
OFFICE OF THE MIAMI COUNTY ENGINEER

2100 N. County Road 25-A, Troy, Ohio 45373  
Telephone: (937) 440-5656 Fax: (937) 440-5659  
E-mail: [MCEO@MiamiCountyOhio.gov](mailto:MCEO@MiamiCountyOhio.gov)

Paul P. Huelskamp, PE, PS  
Miami County Engineer

APPLICANT NAME: AES Ohio DATE: 1/28/2022

ADDRESS: 1900 Dryden Road  
Dayton, OH 45439

TELEPHONE: 937-331-4032

PROJECT LOCATION: Road Name Davis Road Township Union

Address or description of location: Starting at entrance to Barrett Materials (39.989745, -84.351872),  
ending at 5577 Davis Road (39.956734, -84.351209)

TYPE OF INSTALLATION: Underground Overhead Steel Pole Electric Transmission Line Structures

INSTALLATION METHOD:

- ☐ Open cut road crossing ☒ Work adjacent to roadway - within R/W limits  
☐ Boring or tunneling roadway ☐ Other describe under "SPECIAL CONDITIONS"

DESCRIPTION OF WORK:

Trench width n/a Type utility or service Electric Transmission  
Depth of installation 20 feet maximum Type material installing Steel poles with gravel backfill or concrete foundations  
Type structures involved 49 poles Amount/Quantity of work 2.3 miles within road ROW (ft./units)

PROJECT DURATION: Starting date: approx. 2/1/2022 Completion date: approx. 12/31/2022 (restoration)

PERMIT VALID FOR 365 DAYS. After indicated time period permit must be submitted for renewal or extension.

SPECIAL CONDITIONS, comments, or additional information:

Permit application for construction crews to install new transmission line pole structures from County Road shoulder. Traffic flow will be maintained down to  
one lane along county road where crews are working. Traffic control plan will be implemented with flaggers and warning signs.

Miami County Engineer's Office will be notified when work within County Road ROW is to be taking place.

I/We hereby agree to all terms, conditions, and restrictions as stated and apply to the work to be done under this permit. All future responsibilities must be assumed by the applicant, his grantee, successors, and assignees.

SIGNED: Andrew Schieltz Title: Transmission Engineer

Firm: AES Ohio Date: 1/28/2022

PERMIT TO PERFORM WORK AS STATED ON THIS APPLICATION IS HEREBY GRANTED.

Paul P. Huelskamp Date: 1/28/2022  
Paul P. Huelskamp, PE, PS County Engineer

\* Please submit one (1) set of plans for proposed project with this Application.

TOWNSHIP TRUSTEES NOTIFICATION: Date: \_\_\_\_\_ ☐ Approval ☐ Disapproval

Comments: \_\_\_\_\_

\*This application, when signed by the Miami County Engineer, shall serve as a permit as authorized by the Board of Miami County Commissioner's Resolution No. 22-01-38.

\*This permit is also subject to the terms and conditions as listed on page two of this permit.



APPLICATION FOR PERMIT TO WORK WITHIN  
COUNTY/TOWNSHIP ROAD RIGHT-OF-WAY LIMITS  
OFFICE OF THE MIAMI COUNTY ENGINEER  
2100 N. County Road 25-A, Troy, Ohio 45373  
Telephone: (937) 440-5656 Fax: (937) 440-5659  
E-mail: [MCEO@MiamiCountyOhio.gov](mailto:MCEO@MiamiCountyOhio.gov)

Paul P. Huelskamp, PE, PS  
Miami County Engineer

APPLICANT NAME: AES Ohio DATE: 1/28/2022

ADDRESS: 1900 Dryden Road  
Dayton, OH 45439

TELEPHONE: 937-331-4032

PROJECT LOCATION: Road Name Eldean Road Township Concord

Address or description of location: Starting at 3485 Eldean Road (40.075776, -84.269702),  
ending at 3690 Eldean Road (40.075619, -84.274268)

TYPE OF INSTALLATION: Underground Overhead Steel Pole Electric Transmission Line Structures

INSTALLATION METHOD:

- ☐ Open cut road crossing ☒ Work adjacent to roadway - within R/W limits  
☐ Boring or tunneling roadway ☐ Other describe under "SPECIAL CONDITIONS"

DESCRIPTION OF WORK:

Trench width n/a Type utility or service Electric Transmission

Depth of installation 20 feet maximum Type material installing Steel poles with gravel backfill or concrete foundations

Type structures involved 6 poles Amount/Quantity of work 0.25 miles within road ROW (ft./units)

PROJECT DURATION: Starting date: approx. 2/1/2022 Completion date: approx. 12/31/2022 (restoration)

PERMIT VALID FOR 365 DAYS. After indicated time period permit must be submitted for renewal or extension.

SPECIAL CONDITIONS, comments, or additional information:

Permit application for construction crews to install new transmission line pole structures from County Road shoulder. Traffic flow will be maintained down to one lane along county road where crews are working. Traffic control plan will be implemented with flaggers and warning signs.


Miami County Engineer's Office will be notified when work within County Road ROW is to be taking place.

I/We hereby agree to all terms, conditions, and restrictions as stated and apply to the work to be done under this permit. All future responsibilities must be assumed by the applicant, his grantee, successors, and assignees.

SIGNED: Andrew Schieltz Title: Transmission Engineer

Firm: AES Ohio Date: 1/28/2022

PERMIT TO PERFORM WORK AS STATED ON THIS APPLICATION IS HEREBY GRANTED.

 Date: 1/28/2022  
Paul P. Huelskamp, PE, PS County Engineer

\* Please submit one (1) set of plans for proposed project with this Application.

TOWNSHIP TRUSTEES NOTIFICATION: Date: ☐ Approval ☐ Disapproval

Comments:

\*This application, when signed by the Miami County Engineer, shall serve as a permit as authorized by the Board of Miami County Commissioner's Resolution No. 22-01-38.

\*This permit is also subject to the terms and conditions as listed on page two of this permit.





APPLICATION FOR PERMIT TO WORK WITHIN  
COUNTY/TOWNSHIP ROAD RIGHT-OF-WAY LIMITS  
OFFICE OF THE MIAMI COUNTY ENGINEER

2100 N. County Road 25-A, Troy, Ohio 45373  
Telephone: (937) 440-5656 Fax: (937) 440-5659  
E-mail: [MCEO@MiamiCountyOhio.gov](mailto:MCEO@MiamiCountyOhio.gov)

Paul P. Huelskamp, PE, PS  
Miami County Engineer

APPLICANT NAME: AES Ohio DATE: 1/28/2022

ADDRESS: 1900 Dryden Road  
Dayton, OH 45439

TELEPHONE: 937-331-4032

PROJECT LOCATION: Road Name Harter Road Township Union

Address or description of location: Starting at intersection with Horseshoe Bend Road (40.008935, -84.290748),  
ending at intersection with State Road 55 (40.002751, -84.290587)

TYPE OF INSTALLATION: Underground Overhead Steel Pole Electric Transmission Line Structures

INSTALLATION METHOD:

- ☐ Open cut road crossing ☒ Work adjacent to roadway - within R/W limits  
☐ Boring or tunneling roadway ☐ Other describe under "SPECIAL CONDITIONS"

DESCRIPTION OF WORK:

Trench width n/a Type utility or service Electric Transmission

Depth of installation 20 feet maximum Type material installing Steel poles with gravel backfill or concrete foundations

Type structures involved 10 poles Amount/Quantity of work 0.42 miles within road ROW (ft./units)

PROJECT DURATION: Starting date: approx. 2/1/2022 Completion date: approx. 12/31/2022 (restoration)

PERMIT VALID FOR 365 DAYS. After indicated time period permit must be submitted for renewal or extension.

SPECIAL CONDITIONS, comments, or additional information:

Permit application for construction crews to install new transmission line pole structures from County Road shoulder. Traffic flow will be maintained down to  
one lane along county road where crews are working. Traffic control plan will be implemented with flaggers and warning signs.

Miami County Engineer's Office will be notified when work within County Road ROW is to be taking place.

I/We hereby agree to all terms, conditions, and restrictions as stated and apply to the work to be done under this permit. All future responsibilities must be assumed by the applicant, his grantee, successors, and assignees.

SIGNED: Andrew Schieltz Title: Transmission Engineer

Firm: AES Ohio Date: 1/28/2022

PERMIT TO PERFORM WORK AS STATED ON THIS APPLICATION IS HEREBY GRANTED.

Paul P. Huelskamp Date: 1/28/2022  
Paul P. Huelskamp, PE, PS County Engineer

\* Please submit one (1) set of plans for proposed project with this Application.

TOWNSHIP TRUSTEES NOTIFICATION: Date: \_\_\_\_\_ ☐ Approval ☐ Disapproval

Comments: \_\_\_\_\_

\*This application, when signed by the Miami County Engineer, shall serve as a permit as authorized by the Board of Miami County Commissioner's Resolution No. 22-01-38.

\*This permit is also subject to the terms and conditions as listed on page two of this permit.

**This foregoing document was electronically filed with the Public Utilities  
Commission of Ohio Docketing Information System on**

**2/8/2022 5:10:26 PM**

**in**

**Case No(s). 18-1259-EL-BTX**

Summary: Notification of Miami County ROW Permits for West Milton - Eldean  
138kV Line electronically filed by Ms. Sarah Howdeshelt on behalf of The Dayton  
Power and Light Company