



Legal Department

American Electric Power
1 Riverside Plaza
Columbus, OH 43215-2373
AEP.com

May 12, 2022

Ms. Tanowa Troupe, Secretary
Ohio Power Siting Board
180 East Broad Street
Columbus, Ohio 43215-3793

Hector Garcia
Senior Counsel –
Regulatory Services
(614) 716-3410 (P)
hgarcia1@aep.com

**RE: Proof of Compliance with Condition
Case No. 21-1111-EL-BNR,
Biers Run – Circleville 138kV Line Cut-In Project**

Dear Ms. Troupe:

In satisfaction of Condition (2) of the Staff Report for this Project, AEP Ohio Transmission Company submits this notice and attachment to inform you that the Telecom County Approval has been approved for the above-referenced Project.

If you have any questions regarding this information, please do not hesitate to contact me.

Respectfully submitted,

/s/ Hector Garcia

Hector Garcia (0084517), Counsel of Record
Counsel for AEP Ohio Transmission Company, Inc.

cc: John Jones, Counsel OPSB Staff
Jon Pawley, OPSB Staff

From: [Bostic, Shelby](#)
To: [Dean L Sutton](#); [Kristen L Matija](#)
Cc: [Shepherd, Jamie](#)
Subject: [EXTERNAL] Biers Run-Circleville-Lutz STA-Ross County Approved Permit
Date: Thursday, May 12, 2022 8:58:28 AM
Attachments: [image001.png](#)

This is an **EXTERNAL** email. **STOP. THINK** before you CLICK links or OPEN attachments. If suspicious please click the '**Report to Incidents**' button in Outlook or forward to incidents@aep.com from a mobile device.

Dean,

Please see below email from Ross County Engineer. Our permit was approved, with written confirmation. Please make sure fiber is at minimum 72" as agreed on with the engineer. Please let me know if there is any questions. I made him aware you may start as soon as next week.

Thanks!



Shelby Bostic
Right of Way Agent

📞 614-741-8702
sbostic@actalentservices.com

8100 Walton Parkway | New Albany, OH 43054
actalentservices.com

This electronic mail (including any attachments) may contain information that is privileged, confidential, and/or otherwise protected from disclosure to anyone other than its intended recipient(s). Any dissemination or use of this electronic mail or its contents (including any attachments) by persons other than the intended recipient(s) is strictly prohibited. If you have received this message in error, please notify us immediately by reply e-mail so that we may correct our internal records. Please then delete the original message (including any attachments) in its entirety. Thank you

From: Deric Cox <dericcox@rosscountyohio.gov>
Sent: Thursday, May 12, 2022 8:07 AM
To: Bostic, Shelby <sbostic@actalentservices.com>
Subject: Re: Permit for work in Ross County, CR-101

Shelby,

Your permit application is approved with the stipulation that the cables be installed at a depth of 72" minimum below the ground line and not at 42" minimum as was shown on the submitted plans.

Best regards,

Deric Cox, P.E.

Ross County Engineer's Office
PO Box 458
755 Fairgrounds Road
Chillicothe, OH 45601

740-702-3130
dericcox@rosscountyohio.gov

On Wed, May 11, 2022 at 2:34 PM Bostic, Shelby <sbostic@actalentservices.com> wrote:

Deric,

The Telecom Engineer said we could go to 72" for the underground fiber. Thanks!



Shelby Bostic
Right of Way Agent

☎ 614-741-8702
sbostic@actalentservices.com

8100 Walton Parkway | New Albany, OH 43054
actalentservices.com

This electronic mail (including any attachments) may contain information that is privileged, confidential, and/or otherwise protected from disclosure to anyone other than its intended recipient(s). Any dissemination or use of this electronic mail or its contents (including any attachments) by persons other than the intended recipient(s) is strictly prohibited. If you have received this message in error, please notify us immediately by reply e-mail so that we may correct our internal records. Please then delete the original message (including any attachments) in its entirety. Thank you

From: Deric Cox <dericcox@rosscountyohio.gov>
Sent: Thursday, May 5, 2022 9:25 AM
To: Bostic, Shelby <sbostic@actalentservices.com>
Subject: Permit for work in Ross County, CR-101

Hello Shelby,

Attached please find an application for a permit to perform work in the County right-of-way. Since you have already provided the plans for the work to us, you can just return to us the completed application.

Best regards,

Deric Cox, P.E.

Ross County Engineer's Office
PO Box 458
755 Fairgrounds Road
Chillicothe, OH 45601

740-702-3130
dericcox@rosscountyohio.gov

**This foregoing document was electronically filed with the Public Utilities
Commission of Ohio Docketing Information System on**

5/12/2022 2:06:24 PM

in

Case No(s). 21-1111-EL-BNR

Summary: Notice Proof of Compliance with Condition electronically filed by Hector Garcia-Santana on behalf of AEP Ohio Transmission Company, Inc.