



Legal Department

American Electric Power
1 Riverside Plaza
Columbus, OH 43215-2373
AEP.com

June 21, 2022

Ms. Tanowa Troupe, Secretary
Public Utilities Commission of Ohio
180 East Broad Street
Columbus, Ohio 43215-3793

Hector Garcia
Senior Counsel –
Regulatory Services
(614) 716-3410 (P)
hgarcia1@aep.com

**RE: Amended Pre-Application Notification Letter
In the matter of the Letter of Notification Application of Ohio Power
Company for a Certificate of Environmental
Compatibility and Public Need for the Arboles Station 138 kV
Transmission Line Adjustment Project in Case No. 22-0447-EL-BLN**

Dear Ms. Troupe:

The Ohio Power Company (the “Company”) files this pre-application notification letter for the above-reference Project pursuant to Rule 4906-6-03(A) of the Ohio Administrative Code.

The Company is proposing the Arboles Station 138 kV Transmission Line Adjustment Project (the “Project”), in Scioto Township, Pike County, Ohio. The Project consists of rebuilding and rerouting existing 138 kV transmission lines to serve the new Arboles Station (21-1084-EL-BLN) from Don Marquis, Waverly, and South Lucasville stations.

0.3 miles of the existing Lucasville-Sargents 138 kV line will be rerouted into Arboles Station on new structures and centerline while 0.5 miles of the existing line will be removed, bypassing the Sargents Station. In addition, 0.3 miles of the Waverly-Sargents 138 kV line will be rebuilt from a single circuit line to a double circuit line and routed into Arboles Station with 0.05 miles of new centerline, removing 0.3 miles of this line asset. Additionally, the Don Marquis 138 kV Loop No. 2 will be modified from a double circuit to operate as a six-wired single-circuit configuration by installing jumper loops between the existing double circuit conductors.

The above-mentioned line work creates 3 circuits connected to Arboles Station. Arboles-South Lucasville 138 kV circuit, Arboles-Waverly 138 kV circuit, and Arboles-Don Marquis 138 kV circuit. Eliminating the Don Marquis-South Lucasville 138 kV circuit, and the Don Marquis-Waverly No. 1 138 kV circuit.

The Company anticipates that construction of the Project will begin in the September 2022. The anticipated in-service date for the Project is May 2023.

Respectfully submitted,

/s/ Hector Garcia

Hector Garcia (0084517), Counsel of Record
Counsel for AEP Ohio Transmission Company, Inc.

cc: John Jones, Counsel OPSB Staff
Jon Pawley, OPSB Staff

**This foregoing document was electronically filed with the Public Utilities
Commission of Ohio Docketing Information System on
6/21/2022 11:54:06 AM**

in

Case No(s). 22-0447-EL-BLN

Summary: Notification Amended Pre-Application Notification Regarding the Arboles
Station Project electronically filed by Hector Garcia-Santana on behalf of Ohio
Power Company