AES Ohio 1900 Dryden Road Dayton, Ohio 45439

September 19, 2022

Chairman Jenifer French Ohio Power Siting Board 180 East Broad Street Columbus, Ohio 43215

Re: Sidney – Franklin Honda 138kV Rebuild/Extension Project PUCO Case No. 22-0140-BLN Proof of Compliance with Ohio Administrative Code 4906-6-08

Dear Chairman French,

The Dayton Power and Light Company (DP&L) doing business as "AES Ohio" hereby files this proof of compliance with the notice requirements set forth in Rule 4906-6-08 of the Ohio Administrative Code for the above-referenced project application. In accordance with OAC 4906-6-08(A), AES Ohio published public notices of the Letter of Notification in the newspaper of general circulation in the project's area on September 6, 2022 (Enclosure 1).

Respectfully submitted,

ss:/ Randall V. Griffin

Randall V Griffin (Ohio Bar No. 0080499) Chief Regulatory Counsel AES Ohio 937-479-8983 (cell) Randall.griffin@aes.com

Enclosures: (1) Publisher's affidavit and proof of general circulation in area newspaper



Enclosure 1 Publisher's Affidavit and Proof of General Circulation in Area Newspaper



Affidavit of Publication

STATE OF OHIO } SS COUNTY OF SHELBY }

Diana Sleppy, being duly sworn, says:

That she is Customer Service/Sales of the SIDNEY DAILY NEWS, a daily newspaper of general circulation, printed and published in SIDNEY, SHELBY County, OHIO; that the publication, a copy of which is attached hereto, was published in the said newspaper on the following dates:

Sep 6,2022

That said newspaper was regularly issued and circulated on those dates.

SIGNED:

Subscribed to and sworn to me this 6th day of Sep 2022

Teresa S. Ketring, SHELBY County, OHIO

My commission expires RIAPpl 4, 2024

Teresa S. Ketring

Notary Public-State of Ohio

\$ 315.00

50007951

70298838

317-570-6800


GAI Consultants Kim Mendez 201 North Illinois Street Suite 1700 INDIANAPOLIS, IN 46204

Notice of Proposed Major Utility Facility

The Dayton Power and Light Company doing business as "AES Ohio" is proposing the construction of the AES Ohio Sidney - Franklin Honda 138kV Rebuild/Extension Project ("the Project"). AES Ohio is planning the partial rebuild of 5.3-miles of the existing 6628 Sidney - Amsterdam 69kV transmission line and the installation of the new 1.9-mile 13854 Sidney - Franklin 138kV transmission line. The new 13854 line will be constructed on a segment of the existing single circuit 6628 line. To support the new 13854 line, the existing single circuit transmission line pole structures of the existing 6628 line will need to be removed and replaced with double-circu 69kV/138kV pole structures. The installation of the new 13854 Sidney - Franklin 138l transmission line will begin at structure 246102, near the intersection of State Ro 29 and Kuther Road, of the existing 6628 Sidney - Amsterdam 69kV transmiss u. line and continue to the new Franklin Substation. The line rebuild with the addis J of a 138kV circuit to the existing lines, and the new 138kV transmission line route h allow for the reliable supply of 138kV sources to the new Franklin substation. Ild proposed Project is needed to improve the resilience and reliability of the area pron system, increase operational flexibility, and to meet the requirements of HDMASt the surrounding transmission network. The proposed Project is located in Front and Turtle Creek Townships, as well as the city of Sidney within Shelby County, Stea In accordance with Ohio Administrative Code (OAC) Rule 4906-06-05, the Projet mc within the Ohio Power Siting Board (OPSB) requirements for a Letter of Notifinsh (LON) Application. The following public officials and agency departments have a t provided a copy of the Project LON Application:

- · Julie Ehemann, Shelby County Commissioner
- · Robert Guillozet, Shelby County Commissioner
- · Anthony Bornhorst, Shelby County Commissioner
- · Robert Geuy, Shelby County Engineer
- · Alexander Berner, Franklin Township Board of Trustees
- · Alan Michael, Franklin Township Board of Trustees
- Roger Schulze, Franklin Township Board of Trustees
- Dustin Cole, Turtle Creek Township Board of Trustees
- Jonathan Siegrist, Turtle Creek Township Board of Trustees
- Douglas Ike, Turtle Creek Township Board of Trustees
- Mardie Milligan, Mayor and City of Sidney Council Member
- Steve Wagner, Vice Mayor and City of Sidney Council Member
- · Joe Moniaci, City of Sidney Council Member
- Scott Roddy, City of Sidney Council Member
- Mike Barhorst, City of Sidney Council Member
- Steve Klingler, City of Sidney Council Member
- Jenny VanMatre, City of Sidney Council Member
- Andrew Bowsher, City of Sidney Manager
- Randy Magoto, P.S., City of Sidney Engineer

The Application is available for public inspection at the Amos Memorial Public Library, 230 E. North Street, Sidney, OH 45365; and at the Ohio Power Siting Board, 180 East Broad Street, Columbus, Ohio 43215. The OPSB phone number is 1-866-270-6772 and their general email address is contactopsb@puc.state.oh.us. Viewing an electronic version of the Application can be performed by visiting the OPSB website https://www.opsb.ohio.gov/ and searching by Case Number 22-0140-EL-BLN. Project information and how to request a copy of the Application can be found on AES Ohio's website https://www.aes-ohio. com/transmission-improvements. The Project has been assigned Case Number 22-0140-EL-BLN and the LON to construct, operate, and maintain the Project is now pending before the OPSB. Interested persons may file motions to intervene and/ or file comments within 10 days of the date of this publication, in accordance with rule 4906-2-12 of the Ohio Administrative Code.



s au

the

iou

This foregoing document was electronically filed with the Public Utilities Commission of Ohio Docketing Information System on

9/19/2022 9:11:07 AM

in

Case No(s). 22-0140-EL-BLN

Summary: Notification of Proof of Compliance with Ohio Administrative Code 4906-6-08 for Sidney – Franklin Honda 138kV Rebuild/Extension Project electronically filed by Ms. Sarah Howdeshelt on behalf of Dayton Power & Light Company d/b/a AES Ohio