



Legal Department

American Electric Power
1 Riverside Plaza
Columbus, OH 43215-2373
AEP.com

October 21, 2022

Ms. Tanowa Troupe, Secretary
Ohio Power Siting Board
180 East Broad Street
Columbus, Ohio 43215-3793

Hector Garcia
Senior Counsel –
Regulatory Services
(614) 716-3410 (P)
hgarcia1@aep.com

**RE: Case No. 22-0918-EL-BLN
Vine-City of Columbus West 138 kV Transmission Line Relocation Project
Notice of Adjustments**

Dear Ms. Troupe:

Ohio Power Company (the “Company”) is submitting the following information to correct the Company’s application that was submitted on October 14, 2022 for the above-referenced Project.

The Company submits revised information regarding the static wire that was provided in 4906-6-05 B(9) Technical Features. The corrected static wire information is listed below.

Static Wire: 500 kcmil ground continuity conductor

If you have any questions regarding this information, please do not hesitate to contact me.

Respectfully submitted,

/s/ Hector Garcia

Hector Garcia (0084517), Counsel of Record
Counsel for Ohio Power Company.

cc: John Jones, Counsel OPSB Staff
Jon Pawley, OPSB Staff

**This foregoing document was electronically filed with the Public Utilities
Commission of Ohio Docketing Information System on**

10/21/2022 10:53:13 AM

in

Case No(s). 22-0918-EL-BLN

Summary: Correspondence Supplemental Information Provided. electronically filed
by Hector Garcia-Santana on behalf of Ohio Power Company