

**AEP OHIO TRANSMISSION COMPANY'S RESPONSE TO  
OHIO POWER SITING BOARD STAFF'S  
DISCOVERY REQUEST  
OPSB CASE 23-0040-EL-BLN  
THIRD SET**

**INTERROGATORY**

DR-03-001                      1) Would this Project replace the existing conductor with the 795 kcmil 26/7 ACSR mentioned in the 'Technical Features' of page 4 of the Application? If so, please describe the existing conductor.

**RESPONSE**

The Project will replace the existing 636 kcmil AA/1350 37 Strand conductor with the 795 kcmil 26/7 ACSR conductor identified on page 4 of the Application.

**This foregoing document was electronically filed with the Public Utilities  
Commission of Ohio Docketing Information System on**

**3/23/2023 4:54:51 PM**

**in**

**Case No(s). 23-0040-EL-BLN**

Summary: Response To Staff's 3rd Discovery Request electronically filed by Hector Garcia-Santana on behalf of AEP Ohio Transmission Company, Inc..