
AES Ohio
1065 Woodman Drive
Dayton, Ohio 45432

June 8, 2023

Chair Jenifer French
Ohio Power Siting Board
180 East Broad Street
Columbus, Ohio 43215

Re: **Pre-Application Notification Letter
In the matter of the Letter of Notification Application of AES Ohio for a Certificate of
Environmental Compatibility and Public Need for the
Fayette Substation & 138kV Extension Project
Ohio Power Siting Board Case No. 23-0067-EL-BLN**

Dear Chair French,

The Dayton Power and Light Company d/b/a AES Ohio files this Pre-Application Notification Letter for the above-referenced project pursuant to Rule 4906-6-03(A) of the Ohio Administrative Code ("OAC").

AES Ohio is proposing the construction of the Fayette Substation and 138 kilovolt ("kV") Extension Project ("the Project"), located southwest of Jeffersonville in Jefferson Township, within Fayette County Ohio. The proposed Project involves the construction of the new approximately 19.7-acre 345kV Fayette Substation and a 138kV extension that will involve building two single-circuit parallel lines of approximately 0.47 miles each, spanning from the proposed Fayette Substation to a 138kV delivery point. The new Fayette Substation will step service down from 345kV to 138kV and 69kV and have a breaker and half 345kV design, two 345/138kV 450MVA transformers, a breaker and half 138kV design, a 138/69kV 200MVA megavolt ampere (MVA) transformer, 138kV capacitor, and 69kV feed to a new substation named Panther Substation.

In accordance with OAC Rule 4906-06-05, this Project falls within the Ohio Power Siting Board (OPSB) requirements for a Letter of Notification (LON) application.

AES Ohio anticipates that construction of the Project will begin September 15, 2023, pending approval of this Letter of Notification. The anticipated in-service date for the Project is August 1, 2024.

Please feel free to contact me if you have any questions regarding this notification letter.

Respectfully submitted,

/s/ Christopher C. Hollon
Christopher C. Hollon (Ohio Bar No. 0086480)
AES OHIO
1065 Woodman Drive
Dayton, Ohio 45432
Phone: (937) 259-7358
christopher.hollon@aes.com

**This foregoing document was electronically filed with the Public Utilities
Commission of Ohio Docketing Information System on**

6/8/2023 12:44:23 PM

in

Case No(s). 23-0067-EL-BLN

Summary: Letter of Notification for Pre-Application for a Certificate of Environmental Compatibility and Public Need for the Fayette Substation & 138kV Extension Project electronically filed by Ms. Sarah Howdeshelt on behalf of Dayton Power & Light Company d/b/a AES Ohio.