

August 21, 2023

Ms. Tanowa Troupe  
Docketing Division, Ohio Power Siting Board  
The Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**PRE-APPLICATION NOTIFICATION LETTER**  
**Beaver-Black River 138 kV Transmission Line Tap to Serve AMPT Project**  
**Case No. 23-0785-EL-BNR**

Dear Ms. Troupe:

In accordance with Ohio Administrative Code (“OAC”) Rule 4906-6-03(A) and OAC Chapter 4906-6 generally, this letter serves as the pre-application notification letter of applicant American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, for the above-referenced Project. ATSI expects to file a Construction Notice application with the Ohio Power Siting Board shortly.

In this Project, ATSI is proposing to construct a tap from the existing Beaver-Black River 138 kV Transmission Line and extending to substation facility owned by AMP Transmission L.L.C. (“AMPT”). The new transmission line tap will have a length of approximately 30 feet (.01 miles) and require installation of one (1) new, double-circuit, steel-pole structure. The Project is in the City of Amherst, Lorain County, Ohio.

If approved, construction on this Project is expected to begin as early as September 19, 2023 and be completed by October 31, 2023.

For outage coordination purposes, please be advised that ATSI requests a 21-day expedited review for this Project pursuant to Ohio Administrative Code 4906-6-04.

Sincerely,



Michael A. DeSarro  
Transmission Specialist II  
Transmission and Substation Design  
FirstEnergy Service Company

**This foregoing document was electronically filed with the Public Utilities  
Commission of Ohio Docketing Information System on**

**8/21/2023 7:03:47 PM**

**in**

**Case No(s). 23-0785-EL-BNR**

Summary: Correspondence Pre-Application Notification Letter electronically filed by  
Ms. Devan K. Flahive on behalf of American Transmission Systems Incorporated.