



Legal Department

American Electric Power  
1 Riverside Plaza  
Columbus, OH 43215-2373  
AEP.com

October 9, 2023

Ms. Tanowa Troupe, Secretary  
Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, Ohio 43215-3793

**Hector Garcia**  
Senior Counsel –  
Regulatory Services  
(614) 716-3410 (P)  
[hgarcia1@aep.com](mailto:hgarcia1@aep.com)

**RE: Pre-Application Notification Letter  
In the matter of the Construction Notice Application of AEP Ohio  
Transmission Company Inc. for a Certificate of Environmental  
Compatibility and Public Need for the Three Creeks 138 kV Switch Bypass  
Pole Project in Case No. 23-0920-EL-BNR**

Dear Ms. Troupe:

AEP Ohio Transmission Company Inc. (the “Company”) files this pre-application notification letter for the above-reference Project pursuant to Rule 4906-6-03(A) of the Ohio Administrative Code.

The Company proposes to construct the Three Creeks 138 kV Switch Bypass Project (the “Project”) in the City of Groveport, Franklin County, Ohio. The Project requires installing a new bypass pole and approximately 100 feet of conductor. The Project will allow the Company to temporarily reroute power between the Griffin Wheel Extension 138 kV and the Bixby-Groves Road 138 kV transmission lines and de-energize the Three Creeks Switch during maintenance activities.

The Company anticipates that construction of the Project will begin in January 2024. The anticipated in-service date for the Project is January 2024.

Respectfully submitted,

*/s/ Hector Garcia*  
\_\_\_\_\_  
Hector Garcia (0084517), Counsel of Record  
Counsel for AEP Ohio Transmission Company, Inc.

cc: John Jones, Counsel OPSB Staff  
Jon Pawley, OPSB Staff

**This foregoing document was electronically filed with the Public Utilities  
Commission of Ohio Docketing Information System on**

**10/9/2023 2:26:39 PM**

**in**

**Case No(s). 23-0920-EL-BNR**

Summary: Correspondence Pre-application Letter. electronically filed by Hector Garcia-Santana on behalf of AEP Ohio Transmission Company, Inc..