

FILE

Staff Investigation Report and Recommendation

Case No.: 06-150-EL-BLN
Project: Beckett Ridge Tap
Applicant: Cincinnati Gas & Electric Company

Report Date: 7 March 2006

Automatic Approval Date: 14 March 2006 (Letter of Notification process)

Waiver Requests: None

Inspection Date(s): 8 February 2006
Staff Assigned: J. O'Dell

Summary of Staff Recommendations (see report text for discussion):

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- None

Projected Docket Closure Date (if automatically approved): 1 June 2008

Investigation Report

Project Description: This project involves the addition of two sets of 138 kV conductors to a steel lattice tower; each conductor would be approximately 110 feet in length. In addition, two wood pole structures would be installed approximately 75 feet from the tower, within the existing transmission line alignment. The project is necessary to provide an electrical supply to the Beckett Substation.

Site Description: The project is adjacent to the Beckett Ridge Country Club Equipment Maintenance Garage. This project is located in West Chester (formerly Union) Township, Butler County.

Discussion/Comments/Concerns:

The construction of this project should pose only minimal negative social and environmental impacts.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician [Signature] Date Processed 3-8-06

RECEIVED-DOCKETING DIV
2006 MAR -7 PM 5:20
PUCO