



American Transmission Systems, Inc.
a subsidiary of FirstEnergy Corp

76 South Main Street
Akron, OH 44308-1890

November 21, 2000

James Hartung
President, Director of the Toledo Port Authority
One Maritime Plaza, Suite 700
Toledo, OH 43604

Dear Mr. Hartung:

RECEIVED
00 NOV 22 AM 11:33
PUCO

Construction Notice
Bay Shore-Jeep No. 2 - 138 kV Transmission Line Relocation
For Tiffin Avenue Bridge - OPSB Case No. 00-2246-EL-BNR

American Transmission Systems, Inc., a wholly owned subsidiary of FirstEnergy Corp., is proposing to relocate a 0.15 mile section of the Bay Shore-Jeep No. 2 138 kV Transmission Line to facilitate the Ohio Department of Transportation's construction of the Tiffin Avenue Bridge. The project involves installing one new steel pole, raising the conductors and removing an existing steel lattice tower. The centerline of the transmission line will be slightly modified as a part of this project. No additional right-of-way is required. The project is located in the City of Toledo in Lucas County, Ohio. The project is located approximately 1,500 feet east of the intersection to Tiffin Avenue and Millard Avenue.

In accordance with the provisions of Ohio Administrative Code (OAC) Rule 4906-1-01, this project falls within the Ohio Power Siting Board's ("OPSB") requirements for a Construction Notice. In compliance with OAC 4906-5-03(B) we have prepared and filed the attached Construction Notice with the OPSB for its review and approval. OAC 4906-15-09(B) requires us to notify you about the project and provide you with a copy of the Construction Notice. As provided in OAC 4906-5-03(B)(3), construction of the project may begin on the planned date of commencement of construction provided in the construction notice, unless notified by the OPSB that the project does not qualify as a construction notice. In accordance with OAC 4906-1-03, we have also filed the enclosed Motion to Waive the Sixty Day filing requirement of OAC 4906-5-03(B)(1).

I'll be glad to answer any question concerning this matter. You can contact me at (330) 384-5225, or Ted Krauss at (330) 761-4268.

Very truly yours,

Thomas C. Burgess, Manager
Transmission Regulatory Affairs

attachment

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business
Technician T.M.A. Date Processed 2-16-01