

FILE

120 pgs

BEFORE
THE OHIO POWER SITING BOARD

RECEIVED-DOCKETING DIV

JAN 19 PM 4:12

PUCO

In the Matter of the Application of Duke)
Energy Madison II, LLC for a Certificate of)
Environmental Compatibility and Public)
Need to Construct 640 MW Peaking Facility)
in Butler County, Ohio.)

Case No. 00-1566-EL-BGN

RESPONSE OF DUKE ENERGY MADISON II, LLC
TO THE STAFF'S FIRST SET OF DATA REQUESTS

Pursuant to Ohio Administrative Code ("OAC") Rule 4906-7-07(D), Applicant, Duke Energy Madison II, LLC ("Duke Energy Madison II"), responds to the following interrogatories and requests for production of documents propounded by the Staff of the Ohio Power Siting Board as follows:

1. Provide any system impact studies that analyze the effects of adding the proposed generating facility to the regional transmission grid for the year and season in which the proposed facility is scheduled to begin commercial operation. These studies should include the following:
 - (a) A detail discussion, analysis, graphs, charts, diagrams, summary and data of load flow, stability and short circuit studies with and without the proposed facility.
 - (b) Discuss testing criteria used for the studies and show any relation to standard industry test criteria used for these studies.
 - (c) Provide transcription diagrams of load flow base-case and contingency-case conditions studied along with an explanation of what the diagrams show.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician Anna K. [Signature] Date Processed Jan 22, 2001

- (d) Identify transmission conditions that fail to meet the criteria along with why they fail to meet the criteria.
- (e) Discussion of remedies to problems found and studies that specifically identify all system additions, modifications or up-grades required by the transmission system operator prior to the facility being interconnected.
- (f) Identify existing or future generating sources modeled in the study. At a minimum, the model should include all existing and planned generating resources for the year and season in which the proposed facility is scheduled to begin commercial operation.
- (g) Identify any future system up-grades include in the studies.
- (h) Identify the effects of power transfer from the proposed facility to areas beyond the service area of the interconnecting company.

ANSWER:

The Cinergy System Impact Study for the Duke Energy Madison II facility is attached as Exhibit A.

2. Provide a summary discussion of the typical hours, days, time of day and months of the year when the generating facility is estimated to operate.

ANSWER:

Duke Energy Madison II anticipates that the facility will operate during peak electric load demand periods. In Ohio and the Midwest, these periods typically occur during the summer months of the year during weekday, daytime hours.

3. Provide or make available for staff review copies of correspondence, meeting notes or joint study reports provided to and received from neighboring interconnected transmission owner/operators concerning the project.

ANSWER:

The Cinergy System Impact Study was reviewed by American Electric Power and Dayton Power & Light prior to issuance to Duke Energy Madison II.

4. Provide information on who will construct, own, operate and maintain the interconnection transmission line, substation and associated facilities.

ANSWER:

Duke Energy Madison II will construct, own, operate and maintain the transmission facilities at the plant and the short transmission line between the plant and the Cinergy Woodsdale substation.

5. Describe how generation dispatch will be carried out, its coordination with the regional transmission system and who will be responsible for dispatch of the facility.

ANSWER:

Duke Energy Madison II will be part of a generator-only control area. The generator-only control area for the plant will coordinate generation dispatch and interchange schedules with the Cinergy control area operator.

6. Provide a list of agreements and/or contracts that the applicant will have to sign with the interconnecting transmission owner before the facility can begin commercial operation.

ANSWER:

Duke Energy Madison II will enter into a Facilities Construction Agreement and an Interconnection Agreement with Cinergy prior to commercial operation. Duke Energy Madison II will also enter into a Station Service Power Agreement for backfeed power, as well as Test/Commissioning Power Purchase Agreement.

7. Provide a copy of (or details of) the interconnect agreement between the applicant and the interconnecting transmission owner/operator.

ANSWER:

The interconnection agreement between Duke Energy Madison II and Cinergy has not been completed as of the date of this filing. A copy of the interconnection agreement can be provided once the agreement is completed.

8. Provide a discussion of whom or where the applicant plans to sell power to; and how the applicant plans to market its power from the proposed facility.

ANSWER:

Duke Energy Madison II will enter into an agreement with an affiliate, Duke Energy Trading and Marketing, L.L.C. ("DETM"), to market power from the proposed facility. Power from the proposed facility is expected to be sold by DETM to wholesale electric customers throughout Ohio and the Midwest.


9. **Discuss any firm power contracts for power from the proposed facility that the applicant has committed to.**

ANSWER:

Duke Energy Madison II has no firm power contracts to sell power from the facility at this time.

CERTIFICATE OF SERVICE

I hereby certify that a true copy of the foregoing **RESPONSE OF DUKE ENERGY MADISON II, LLC TO THE STAFF'S FIRST SET OF DATA REQUESTS** was served by regular U.S. mail, postage prepaid, or hand-delivered, upon the following parties of record, this 19th day of January 2001.


Sally W. Bloomfield

PARTIES OF RECORD:

Matthew J. Satterwhite
Assistant Attorney General
Public Utilities Section
180 E. Broad Street, 9th Floor
Columbus, Ohio 43215
(614) 466-4395
Fax: (614) 644 8764

Report

.....

***System Impact Study for
Madison II Interconnection***

Prepared for
Cinergy Services, Inc.

Submitted by


Ramon Tapia
Executive Consultant

Paloma de Arizon
Senior Consultant

Consulting Services

January 9, 2001

Report No. R53-00



POWER TECHNOLOGIES


A Shaw Group Company

Table of Contents

Section 1 Introduction	1-1
1.1 Project Description.....	1-1
1.2 Project Tasks.....	1-1
1.2.1 Database Development.....	1-1
1.2.2 AC Contingency Analysis.....	1-1
1.2.3 Transmission System Reinforcements.....	1-1
1.2.4 Power Transfer Capability.....	1-1
1.2.5 Stability Analysis.....	1-2
Section 2 Data Preparation	2-1
2.1 Madison II Interconnection and Plant Data.....	2-1
2.2 Power Flow Cases.....	2-1
2.2.1 Steady State Analyses.....	2-1
2.2.2 Stability Analysis.....	2-1
2.3 Input Data Files.....	2-2
2.4 Dynamics Data File.....	2-2
Section 3 AC Contingency Analysis	3-1
3.1 Methodology.....	3-1
3.2 Disturbance and Performance Criteria.....	3-1
3.3 Results.....	3-1
3.3.1 Thermal Assessment.....	3-1
3.3.2 Voltage Assessment.....	3-3
Section 4 Reinforcements	4-1
4.1 Reinforcements.....	4-1

TABLE OF CONTENTS

4.2	Estimated Costs.....	4-3
Section 5 Linear Transfer Analysis		5-1
5.1	Methodology	5-1
5.2	Disturbance and Performance Criteria.....	5-1
5.3	Results	5-1
Section 6 Stability Analysis		6-1
6.1	Disturbance and Performance Criteria.....	6-1
6.2	Results	6-3
Section 7 Short Circuit Analysis		7-1
	Fault Current.....	7-1
Section 8 Conclusions		8-1
Appendix A.....		A-1
Appendix B Plant Data Summary		B-1
Appendix C AC Contingency Analysis Summary.....		C-1
Appendix D		D-1



POWER TECHNOLOGIES
A Shaw Group Company

Notice

This study addresses the feasibility of integrating the proposed merchant plant into the Cinergy transmission system at the point of receipt and does not address the Availability of Transmission Capacity (ATC) to transfer the output of the proposed plant to specific points of delivery. A Transmission Request Study will be required when a Transmission Service Request is received.

The use of preliminary data for the combustion turbine generating units, scheduling of other proposed merchant plants and system projects on Cinergy and neighboring utility systems could affect the study results. Neighboring utility facilities' limitations, of which Cinergy is not aware, could affect study results.

Cinergy is currently studying other merchant plant requests not included in this study which could affect the study results and ATC for this site.

Cinergy recommends the merchant requestor share these studies with Cinergy's neighboring control areas for a review of the impact on their systems.



POWER TECHNOLOGIES
A Shaw Group Company

Executive Summary

This report summarizes power flow and stability analyses conducted by Power Technologies, Inc. (PTI) for Cinergy Services, Inc (Cinergy) to assess the impact of the proposed Madison II 640 MW generating station. Contingency analysis identified some local transmission loading problems which result from adding the Madison II plant into the system. System upgrades, which will be necessary to integrate the requested 640 MW capacity, were identified. The estimated cost of these upgrades is \$33,807,000.

Power transfer capability was estimated from the proposed merchant plant to several neighboring control areas. These estimates are not Available Transfer Capabilities (ATC) or Total Transfer Capability (TTC) as required in FERC Order 888 and 889. Actual ATC's would be determined upon request for transmission service per Cinergy's OATT.

Short circuit calculations show that the addition of 640 MW to the Woodsdale 345 kV Substation bus will increase fault current to several breakers in the area but will not cause any to exceed their fault duty ratings.

Dynamic simulations were performed to assess system performance with and without the plant. Though for all the cases, the system response is stable and positively damped it is noted, damping of oscillations following the disturbance can be fairly low. These results are based on the preliminary dynamic data provided by the merchant plant developer and their equipment vendors. These results could change based on final test data and adjustment of the proposed excitation system parameters. Should the merchant plant developer proceed with the project, Cinergy will work with the merchant plant developer to implement equipment adjustments that will allow the proposed generation to connect to Cinergy's transmission system in a reliable manner. Further stability studies by Cinergy will be required based on the final dynamic data that have been obtained from the original equipment tests and/or settings.

Section

1

Introduction

1.1 Project Description

This report summarizes power flow and stability analyses conducted by Power Technologies, Inc. (PTI) for Cinergy Services, Inc (Cinergy) to assess the impact of the proposed Madison II 640 MW generating station. This new plant will be located near the Woodsdale 345 kV substation in southwest Ohio and will be connected to Cinergy's 345 kV transmission system through this substation.

1.2 Project Tasks

1.2.1 Database Development

Using information provided by Cinergy, power flow and stability models of the proposed plant were developed. The power flow and stability databases were revised to include the proposed generating facility and interconnection.

1.2.2 AC Contingency Analysis

Non-linear ("AC") contingency analysis was conducted to assess post-contingency branch flows and bus voltages in the neighborhood of the proposed plant. This analysis was used to identify local transmission reinforcements required to connect the plant to the transmission system.

1.2.3 Transmission System Reinforcements

With the help of Cinergy's engineering staff, potential transmission reinforcements were identified to rectify circuit overloads attributed to the proposed power plant. A cost estimate was prepared for the reinforcements using typical unit cost data furnished by Cinergy.

1.2.4 Power Transfer Capability

Linear ("DC") transfer analysis was conducted to estimate the power transfer limit between the proposed plant location and several neighboring control areas. These estimates are not Available Transfer Capabilities (ATC) or Total Transfer Capability (TTC) as required in FERC Order 888 and 889. Actual ATC's would be determined upon request for transmission service per Cinergy's OATT.

SECTION 1 INTRODUCTION

1.2.5 Stability Analysis

Dynamic simulations were performed for contingencies selected in consultation with Cinergy's engineering staff to compare system performance with and without the plant.

Section
2

Data Preparation

2.1 Madison II Interconnection and Plant Data

The proposed plant interconnection is shown in Appendix A. Plant data provided by the developer is summarized in Appendix B.

The following assumptions were made:

- The Madison II plant is assumed to be interconnected to the power system at the existing 345 kV Woodsdale substation.
- The plant is connected to the transmission system by a short transmission line with negligible impedance.
- The plant is assumed to consist of 8 machines each generating 80 MW.

2.2 Power Flow Cases

2.2.1 Steady State Analyses

Cinergy provided a PSS/E database as a starting point for the AC contingency and power transfer capability analysis. This database included the following merchant plants, Vermillion at 640 MW, Wheatland at 500 MW, Madison at 640 MW and Worthington at 171 MW. The database represents the system in 2002 under summer peak loading conditions.

Starting with the 2002 case provided by Cinergy, "Madison II_base case", the following change was made to develop a new base case "Madison II_Online" with the Madison II plant on-line:

- The 640 MW Madison II plant was added as described in Section 2.1.

To include the 640 MW Madison II plant in the "Madison II_Online" case, an equal amount of generation was displaced in Consumers Power in Michigan.

2.2.2 Stability Analysis

Cinergy provided a PSS/E database as a starting point for the stability analysis. The database represents the system in 2003 under summer peak conditions. Starting with the

SECTION 2 DATA PREPARATION

2003 case provided by Cinergy, the Madison II plant was added using the assumptions listed in Section 2.1 to develop a new base case "Madison II_Off_DYN_ALL" with the Madison II plant off-line

From the "Madison II_Off_DYN_ALL" case, a case was created with Madison II on-line "Madison II_ON_DYN_ALL" by displacing 640 MW of Consumers Power generation in Michigan.

2.3 Input Data Files

Cinergy provided input data files for the AC contingency analysis and the linear transfer analysis. These files consist of a subsystem file, a monitored element file, and a contingency file.

2.4 Dynamics Data File

The models and parameters for existing generating units in the stability database were provided by Cinergy. Generator, exciter, governor and power system stabilizer (PSS) models for the proposed plant are based on manufacturer information provided by the developer. The models for the proposed plant are listed in Appendix B.

Section
3

AC Contingency Analysis

3.1 Methodology

PTT's MUST (Managing and Utilizing System Transmission) software was used to conduct the AC contingency analysis. The objective of this assessment was to identify any local transmission loading or voltage problems which result from dispatching the Madison II plant. The transmission system was checked in an area bounded approximately by the Miami (DPL) and Bath (DPL) substations to the north, Five Points to the west, Zimmer and E. Bend to the south and Marquis to the east. The critical transmission facilities that were included in this analysis were within five buses of the main 345 kV interconnection point at the Woodsdale substation.

3.2 Disturbance and Performance Criteria

The input data files provided by Cinergy were used for this analysis. The contingency file consists of:

- Generator outages
- Single branch contingencies 138 kV and above and tower and double branch contingencies at the 345 kV level in the Cinergy and neighboring areas.

The contingency file was modified such that an inertial dispatch was simulated for any contingency that resulted in an imbalance between load and generation. The monitored element file consists of lines 69 kV and above in Cinergy's area and lines 138 kV and above in adjacent areas. Branches were monitored for loading above 100% of the long-term emergency rating (Rate B).

Bus voltages in the CG&E subsystem (69 kV and above) were analyzed to identify buses with post-contingency voltages below 92%. Violations with low sensitivity to the Madison II plant (voltage difference of less than 0.5%) were neglected.

3.3 Results

3.3.1 Thermal Assessment

Post-contingency overloads that occur within the area defined in Section 3.1 as a result of the proposed Madison II plant are listed in **Table 3-1**. The details of the worst violation are shown in the table "Frequency of Branch Violations" located in Appendix C.

SECTION 3 AC CONTINGENCY ANALYSIS

Table 3-1: Branch Overloads

Elem#	Monitored Branch			Worst Violation %			
	From Bus	**To Bus**	Ckt Type	Madison II Off-Line	Con # *	Madison II On Line	Con # *
1	8087 CARL M2 69	8089 CARLISLE 69	1 LN	111.6	2	123.1	2
2	8087 CARL M2 69	8090 CARLISLE 138	1 TR	109.4	2	119.2	2
3	8089 CARLISLE 69	17060 090HH W.69	1 LN	107.5	2	127.4	2
4	8464 MILLIKEN 138	8743 TODHUNTR 138	1 LN	110.0	4	172.7	3
5	8052 BETHANY 138	8708 TAP 5485 138	1 LN			110.8	3
6	8411 M. FORT 345	8717 TERMINL 345	1 LN			129.4	1
7	8411 M. FORT 345	8872 WOODSDLE 345	1 LN			136.6	1
8	8464 MILLIKEN 138	8576 P. UN 2 138	1 LN			158.8	3
9	8575 P. UN 1	138 8743 TODHUNTR 138	1 LN			170.6	3
10	8587 PARK 1	138 8589 PARK 2	138 1 LN			111.3	3
11	8708 TAP 5485	138 8743 TODHUNTR 138	1 LN			131.8	3
12	8735 TOD M15	138 8743 TODHUNTR 138	1 LN			126.9	3
13	8735 TOD M15	138 8744 TODHUNTR 345	1 TR			129.6	3
14	8736 TOD M16	138 8743 TODHUNTR 138	1 LN			132.4	3
15	8736 TOD M16	138 8744 TODHUNTR 345	1 TR			135.6	3
16	8737 TOD M17	138 8743 TODHUNTR 138	1 LN			116.7	3
17	8737 TOD M17	138 8744 TODHUNTR 345	1 TR			119.6	3
18	8744 TODHUNTR 345	8872 WOODSDLE 345	1 LN			123.3	5
19	8744 TODHUNTR 345	8872 WOODSDLE 345	2 LN			123.3	6
20	8741 TODHUNTR 69	8792 TX E MNR 69	69 1 LN			102.0	7

* List of Contingencies in Table 3-1

1. Woodsdle to TodHuntr 345 kV Ckt1 & Woodsdle to TodHuntr 345 kV Ckt2
2. Foster to Sugar Creek 345 kV & Foster to Bath 345 kV
3. Woodsdle to M. Fort 345 kV & TodHuntr to Foster 345 kV
4. Miami Fort to Terminal Fort 345 kV & TodHuntr to Foster 345 kV
5. Woodsdle 345 kV to TodHuntr 345 kV Ckt2
6. Woodsdle 345 kV to TodHuntr 345 kV Ckt1
7. Tap 5485 138 kV Union 138 kV

The analysis indicated that there are overloads under contingency conditions in the neighboring area served by DPL. Additional reinforcements at the West Milton substation

may be necessary to eliminate the overloads. Since these facilities are outside of Cinergy's territory, these problems were not pursued further.

3.3.2 Voltage Assessment

In the contingency analysis, the Madison II plant does not cause any bus voltages in the local area to fall below 92%.

Section
4

Reinforcements

The objective of this assessment was to identify possible transmission system reinforcements to rectify the local transmission overloads identified in Section 3.

4.1 Reinforcements

With the help of Cinergy's engineering staff, potential transmission reinforcements were identified to rectify circuit overloads attributed to the proposed power plant. Three reinforcement options were evaluated. Reinforcements for the 138 kV facilities are the same for the three options, but different reinforcement strategies were considered for the 345 kV facilities in each of the three options. Following there is a description of the reinforcements considered for the 345 kV facilities in each one of the aforementioned options.

The first option considers a new Tap on the line from Miami Fort to WMilton 345 kV. The Tap is located at the junction, of the existing Miami Fort to Woodsdale 345 kV and Miami Fort to WMilton 345 kV lines. In addition a line section from Woodsdale to this Tap is considered.

The second option considers the same Tap described in the previous option. In addition it includes a line from Woodsdale to the Tap to West Milton and the rearrangement of the Miami Fort to Woodsdale 345 kV line. The line will be divided into two sections, one section from the Miami Fort 345 kV substation to the Tap and a second section from the Tap to the Woodsdale 345 kV substation.

The third option only considers a line from the Woodsdale 345 kV substation to the WMilton 345 kV substation. There is not Tap considered in this option.

All three options were tested and the second option was chosen, based on the fact that it offers reduced post-contingency flows, increased operating flexibility, and a more robust solution for future developments such as load growth and change in flow patterns. Furthermore for this option peak load losses are 5 MW lower than in option three, though loss savings under other loading conditions will be different. On the other hand the first option still shows overloads as can be seen from Table 4-1.

For the second option four reinforcements are identified:

SECTION 4 REINFORCEMENTS

- 1) A new Tap on the line from Miami Fort to WMilton 345 kV located at the junction of the existing Miami Fort to Woodsdale 345 kV and Miami Fort to WMilton 345 kV lines
- 2) A new 345 kV circuit from the Woodsdale 345 kV substation to the Tap and from the Tap to the 09WMilton 345 kV substation.
- 3) Rearrangement of the Miami Fort to Woodsdale 345 kV line. The line will be divided into two sections, one section from the Miami Fort 345 kV substation to the Tap and a second section from the Tap to the Woodsdale 345 kV substation.
- 4) Reconductoring of the 138 kV line between Millikin and Port Union 2
- 5) Reconductoring of the 138 kV line between Millikin and TodHunter
- 6) Reconductor of the 138 kV line between TodHunter and Port Union 1

The 138 kV lines between Millikin and Port Union 2, Millikin and TodHunter, and TodHunter and Port Union 1 were modeled as two circuits with bundled 954 ACSR conductors. Impedances were calculated assuming both circuits are on the same tower structure.

The case used for AC contingency analysis in Section 3 with Madison II on-line "Madison II_Online" was modified to incorporate the reinforcements listed in Section 4.1. AC contingency analysis was repeated to assess the impact of the reinforcements on branch loading and the results are summarized in Table 4-1.

Table 4-1: Post-Contingency Branch Loading

Elem#	Monitored Branch			Highest Loading %		
	From Bus	**To Bus**	Ckt Type	Reinforcemts Option # 1	Reinforcemts Option # 2	Reinforcemts Option # 3
1	8087 CARL M2 69	8089 CARLISLE69	1 LN	103.9	89.4	94.9
2	8087 CARL M2 69	8090 CARLISLE 138	1 TR	105.2	91.7	96.8
3	8089 CARLISLE69	17060 090HH W.69	1 LN	94.3	68.9	78.8
4	8464 MILLIKEN 138	8743 TODHUNTR 138	1 LN	50.4	43.2	50.4
5	8052 BETHANY 138	8708 TAP 5485 138	1 LN	40.5	34.1	39.5
6	8411 M. FORT 345	8717 TERMINL 345	1 LN	96.5	73.3	75.8
7	8411 M. FORT 345	8872 WOODSDLE 345	1 LN	19.2	—	38.6
8	8464 MILLIKEN 138	8576 P. UN 2 138	1 LN	43.4	36.4	43.4
9	8575 P. UN 1	138 8743 TODHUNTR 138	1 LN	40.5	32.6	41.1
10	8587 PARK 1	138 8589 PARK 2	138 1 LN	26.3	19.7	25.0
11	8708 TAP 5485	138 8743 TODHUNTR 138	1 LN	65.4	57.5	63.0
12	8735 TOD M15	138 8743 TODHUNTR 138	1 LN	70.2	61.3	69.3
13	8735 TOD M15	138 8744 TODHUNTR 345	1 TR	70.2	61.3	69.3
14	8736 TOD M16	138 8743 TODHUNTR 138	1 LN	73.5	64.2	72.5
15	8736 TOD M16	138 8744 TODHUNTR 345	1 TR	73.5	64.2	72.5
16	8737 TOD M17	138 8743 TODHUNTR 138	1 LN	64.8	56.6	64.0
17	8737 TOD M17	138 8744 TODHUNTR 345	1 TR	64.8	56.6	64.0
18	8744 TODHUNTR 345	8872 WOODSDLE 345	1 LN	93.0	76.1	86.5
19	8744 TODHUNTR 345	8872 WOODSDLE 345	2 LN	93.0	76.1	86.5
20	8888 TAP 345	345 8872 WOODSDLE 345	1 LN	117.3	67.3	—
21	8888 TAP 345	345 8872 WOODSDLE 345	2 LN	—	67.3	—
22	8888 TAP 345	345 17090 WMILTON	345 1 LN	115.9	69.4	—
23	8888 TAP 345	345 17090 WMILTON	345 2 LN	—	69.4	—
24	8872 WDSLE	345 17090 WMILTON	345 1 LN	—	—	97.7
25	8741 TODHUNTR 69	8792 TX E MNR69	69 1 LN	93.5	87.4	89.7

4.2 Estimated Costs

A cost estimate for the reinforcements identified in Section 4.1 is developed below. This estimate was prepared using typical construction costs and are not based on detailed engineering estimates.

SECTION 4 REINFORCEMENTS

Table 4-2: Estimated Reinforcement Costs for Option # 2

Element	Units	Unit Cost	Price
Reconductor MILLIKIN to P. UNION 2 138 kV			
Reconductor MILLIKIN to TODHUNTER 138 kV			
Reconductor P. UNION to TODHUNTER 138 kV	9.69 miles	\$300,000/mile	\$2,907,000
New--Woodsdale to Tap 345 kV Section	5.0 miles	\$300,000/mile	\$1,500,000
New-- Tap to WMilton 345 kV Section	18.0 miles	\$300,000/mile	\$5,400,000
New-- Tap to WMilton 345 kV Section	18.0 miles	\$1,000,000/mile	\$18,000,000
New Ring Bus with Six Breakers (At the Tap)	6 breakers	\$1,000,000/bkr	\$6,000,000
Total			\$33,807,000

The above costs do not include the cost to physically connect the proposed generating facility to the transmission system. This cost includes the costs of breakers, transmission facilities from the plant to the Woodsdale 345 kV substation and any other additional equipment needed to accomplish the final interconnection to Cinergy's transmission system.

The cost of additional reinforcement that may be needed in the DPL system is not included in this report.



Section

5

Linear Transfer Analysis

5.1 Methodology

PTT's MUST (Managing and Utilizing System Transmission) software was used to conduct the linear transfer analysis. The objective of this analysis was to estimate the power transfer limit between the proposed plant location and neighboring control areas. These estimates are not Available Transfer Capabilities (ATC) or Total Transfer Capability (TTC) as required in FERC Order 888 and 889. Actual ATC's would be determined upon request for transmission service per Cinergy's OATT.

5.2 Disturbance and Performance Criteria

The input data files provided by Cinergy were used for this analysis. The monitored element file consists of lines 69 kV and above in Cinergy's area and lines 138 kV and above in adjacent areas. Branches were monitored for loading above 100% of the long-term emergency rating (Rate B).

The contingency file consists of:

- Generator outages.
- Single branch contingencies 138 kV and above in the Cinergy and neighboring areas.

The contingency file was modified such that an inertial dispatch was simulated for any contingency that resulted in an imbalance between load and generation.

5.3 Results

In the base case with Madison II off-line "Madison II_basecase" there are several base case and post-contingency overloads in the transmission system. Appendix D contains a list of overloaded branches that are impacted by transfers from Madison II, the number of contingencies for which the element is overloaded with Madison II off-line and the maximum violation with Madison II off-line.

Because the monitored branches listed in Appendix D are overloaded before the Madison II plant is dispatched, Cinergy does not consider them valid limiting branches for transfer analysis. The branches listed in Appendix D were not monitored during the transfer analysis.

SECTION 5 LINEAR TRANSFER ANALYSIS

The areas listed in Table 5-1 and Table 5-2 were identified by Cinergy for transfer analysis. Transfers were simulated from the proposed plant to each of the indicated areas by scaling generation in that area. The complete MUST report is given in Appendix D, the estimated transfer capability from the proposed plant and first five transfer limits are summarized in Table 5-1 and Table 5-2. Table 5-1 shows transfer limits without reinforcements to the transmission system. Table 5-2 shows transfer limits with the reinforcements to the transmission system considered in option two, as indicated in section 4.1 of this report.

SECTION 5 LINEAR TRANSFER ANALYSIS

Table 5-1: Madison II Estimated Transfer Capability Without Reinforcement

To	Transfer Capability	Limiting Element				Contingency			
AEP	229.5	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	229.5	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	363.9	8464 MILLIKIN	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	548.3	8575 P.UN 1	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	618.8	8464 MILLIKIN	138	8576 P.UN 2	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
AMRN	229.9	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	229.9	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	360.9	8464 MILLIKIN	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	539.4	8575 P.UN 1	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	613.9	8464 MILLIKIN	138	8576 P.UN 2	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
DPL	113.8	8741 TODHNTRI69.0		8792 TX E MNR69.0	1	8708 TAP 5485	138	8797 UNION	138 1
	145.1	8758 TP5666-169.0		8792 TX E MNR69.0	1	8708 TAP 5485	138	8797 UNION	138 1
	149.3	8353 JACKSON 69.0		8758 TP5666-169.0	1	8708 TAP 5485	138	8797 UNION	138 1
	196.8	8741 TODHNTRI69.0		8792 TX E MNR69.0	1	8090 CARLISLE	138	8797 UNION	138 1
	215.3	8087 CARL M2 69.0		8089 CARLISLE69.0	1	17079 09SUGRCK	345	8281 FOSTER	345 1
BKPC	229.5	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	229.5	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	255.2	6051 11ADAMS	138	6146 11TYRONE	138 1	6126 11OC TAP	138	6137 11SCOTT	138 1
	299.2	6064 11BRWN P	138	6087 11FANKES	138 1	20007 20AVON	138	20027 20BOONST	138 1
	347.8	6064 11BRWN P	138	6087 11FANKES	138 1	6002 11ALCALD	345	6004 11BRWN N	345 1
HE	230.2	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	230.2	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	358.6	8464 MILLIKIN	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	532.8	8575 P.UN 1	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	587.2	4002 16PETE	345	4042 16PETE	138 E	23 GIBSON	345	1800 GIBSON	138 1
IPL	230.4	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	230.4	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	358.7	8464 MILLIKIN	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	532.8	8575 P.UN 1	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	610.0	8464 MILLIKIN	138	8576 P.UN 2	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
LGEE	27.9	24 SPEED	345	156 SPEED	138 1	6005 11GHENT	345	6015 11W LEXN	345 1
	112.3	24 SPEED	345	156 SPEED	138 1	7064 05JEFRSO	765	7068 05ROCKPT	765 1
	229.6	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	229.6	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	229.8	24 SPEED	345	156 SPEED	138 1	6007 11MIDDLT	345	6013 11TRIMBL	345 1
NIPS	230.2	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	230.2	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	362.7	8464 MILLIKIN	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	543.5	8575 P.UN 1	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	616.9	8464 MILLIKIN	138	8576 P.UN 2	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
OVEC	228.5	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1
	228.5	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	359.2	8464 MILLIKIN	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	538.5	8575 P.UN 1	138	8743 TODHUNTR	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
	610.9	8464 MILLIKIN	138	8576 P.UN 2	138 1	8281 FOSTER	345	8744 TODHUNTR	345 1
SIGE	153.7	1064 TETC 12J69.0		1066 PRINCETO69.0	1	175 OAK CITY	138	178 PRINCETO	138 1
	200.5	1058 OAKLAND 69.0		1064 TETC 12J69.0	1	175 OAK CITY	138	178 PRINCETO	138 1
	229.5	1058 OAKLAND 69.0		3247 10OAKCTY69.0	1	3251 10TOYOTA	138	175 OAK CITY	138 1
	230	8744 TODHUNTR	345	8872 WOODSDLE	345 1	8744 TODHUNTR	345	8872 WOODSDLE	345 2
	230	8744 TODHUNTR	345	8872 WOODSDLE	345 2	8744 TODHUNTR	345	8872 WOODSDLE	345 1

SECTION 5 LINEAR TRANSFER ANALYSIS

Table 5-2: Madison II Estimated Transfer Capability With Reinforcements of Option # 2

To	Transfer Capability	Limiting Element	Contingency
AEP	-1476.2	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	544	17047 09MIAMI 345 17090 09WMILTN 345 1	17089 09WMILTN 138 17090 09WMILTN 345 1
	634.8	8744 TODHUNTR 345 8872 WOODSDLE 345 2	8744 TODHUNTR 345 8872 WOODSDLE 345 1
	634.8	8744 TODHUNTR 345 8872 WOODSDLE 345 1	8744 TODHUNTR 345 8872 WOODSDLE 345 2
	952.8	17047 09MIAMI 345 17090 09WMILTN 345 1	8281 FOSTER 345 8744 TODHUNTR 345 1
AMRN	-1553.9	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	572.8	17047 09MIAMI 345 17090 09WMILTN 345 1	17089 09WMILTN 138 17090 09WMILTN 345 1
	629.7	8744 TODHUNTR 345 8872 WOODSDLE 345 2	8744 TODHUNTR 345 8872 WOODSDLE 345 1
	629.7	8744 TODHUNTR 345 8872 WOODSDLE 345 1	8744 TODHUNTR 345 8872 WOODSDLE 345 2
	987	17047 09MIAMI 345 17090 09WMILTN 345 1	8281 FOSTER 345 8744 TODHUNTR 345 1
DPL	-1125.8	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	275.3	8741 TODHUNTR169.0 8792 TX E MNR69.0 1	8708 TAP 5485 138 8797 UNION 138 1
	308.9	8758 TP5666-169.0 8792 TX E MNR69.0 1	8708 TAP 5485 138 8797 UNION 138 1
	312.9	8353 JACKSON 69.0 8758 TP5666-169.0 1	8708 TAP 5485 138 8797 UNION 138 1
	364.3	8741 TODHUNTR169.0 8792 TX E MNR69.0 1	8090 CARLISLE 138 8797 UNION 138 1
EKPC	-1606.8	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	299.8	6064 11BRWN P 138 6087 11PAWKES 138 1	20007 20AVON 138 20027 20BOONST 138 1
	351.6	6064 11BRWN P 138 6087 11PAWKES 138 1	6002 11ALCALD 345 6004 11BRWN N 345 1
	396.8	20007 20AVON 138 20027 20BOONST 138 1	6064 11BRWN P 138 6087 11PAWKES 138 1
	420.6	6064 11BRWN P 138 6087 11PAWKES 138 1	20027 20BOONST 138 20065 20DALE 138 1
HE	-1627.5	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	591.7	4002 16PETE 345 4042 16PETE 138 E	23 GIBSON 345 180 GIBSON 138 1
	595.2	4002 16PETE 345 4042 16PETE 138 E	178 PRINCETO 138 180 GIBSON 138 1
	603.4	17047 09MIAMI 345 17090 09WMILTN 345 1	17089 09WMILTN 138 17090 09WMILTN 345 1
	607	4002 16PETE 345 4042 16PETE 138 E	4002 16PETE 345 4042 16PETE 138 W
IPL	-1642.3	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	609.7	17047 09MIAMI 345 17090 09WMILTN 345 1	17089 09WMILTN 138 17090 09WMILTN 345 1
	624.3	8744 TODHUNTR 345 8872 WOODSDLE 345 2	8744 TODHUNTR 345 8872 WOODSDLE 345 1
	624.3	8744 TODHUNTR 345 8872 WOODSDLE 345 1	8744 TODHUNTR 345 8872 WOODSDLE 345 2
LGEE	-1668.4	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	60.2	24 SPEED 345 156 SPEED 138 1	6005 11GHENT 345 6015 11W LEXN 345 1
	232.6	24 SPEED 345 156 SPEED 138 1	6007 11MIDDLT 345 6013 11TRIMBL 345 1
	400.3	6075 11CENTRF 138 6145 11TRIMBL 138 1	6007 11MIDDLT 345 6013 11TRIMBL 345 1
	499.8	6013 11TRIMBL 345 6145 11TRIMBL 138 1	6007 11MIDDLT 345 6013 11TRIMBL 345 1
NIPS	-1500.1	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	550.1	17047 09MIAMI 345 17090 09WMILTN 345 1	17089 09WMILTN 138 17090 09WMILTN 345 1
	636.8	8744 TODHUNTR 345 8872 WOODSDLE 345 2	8744 TODHUNTR 345 8872 WOODSDLE 345 1
	636.8	8744 TODHUNTR 345 8872 WOODSDLE 345 1	8744 TODHUNTR 345 8872 WOODSDLE 345 2
	962.7	17047 09MIAMI 345 17090 09WMILTN 345 1	8281 FOSTER 345 8744 TODHUNTR 345 1
OVEC	-1649.6	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	610	17047 09MIAMI 345 17090 09WMILTN 345 1	17089 09WMILTN 138 17090 09WMILTN 345 1
	614.8	8744 TODHUNTR 345 8872 WOODSDLE 345 2	8744 TODHUNTR 345 8872 WOODSDLE 345 1
	614.8	8744 TODHUNTR 345 8872 WOODSDLE 345 1	8744 TODHUNTR 345 8872 WOODSDLE 345 2
SIGE	-1622.9	17089 09WMILTN 138 17090 09WMILTN 345 1	17047 09MIAMI 345 17090 09WMILTN 345 1
	154.9	1064 TETC 12J69.0 1066 PRINCETO69.0 1	175 OAK CITY 138 178 PRINCETO 138 1
	201.8	1058 OAKLAND 69.0 1064 TETC 12J69.0 1	175 OAK CITY 138 178 PRINCETO 138 1
	230.9	1058 OAKLAND 69.0 3247 10OAKCTY69.0 1	3251 10TOYOTA 138 175 OAK CITY 138 1
	349.7	178 PRINCETO 138 1066 PRINCETO69.0 1	175 OAK CITY 138 178 PRINCETO 138 1

Section

6

Stability Analysis

PTT's PSS/E (Power System Simulator) software was used to conduct the stability analysis. The objective of this assessment was to compare system performance with and without the Madison II plant.

6.1 Disturbance and Performance Criteria

Cinergy's reliability criteria states that under normal system peak load conditions with full generation output, all generating units must remain stable with the occurrence of a three phase fault accompanied by a single pole circuit breaker failure with operation of back-up circuit breakers. With one component out-of-service, stable operation of all generating units is to be maintained with a line opening without fault or with a subsequent single phase-to-ground fault accompanied by normal clearing of the fault.

The three-phase faults listed in Table 6-1 were simulated with a single-pole breaker failure. At 3.75 cycles the far end of the faulted line was opened and the stuck breaker condition modeled, and at 6 cycles the fault was cleared.

For the single phase to ground fault, with one element out of service, the contingencies listed in Table 6-1 were simulated with normal clearing after 3.75 cycles (345 kV criteria).

The sequence admittance used to simulate the stuck breaker conditions were given by Cinergy and for the Madison II study are:

- At Woodsdale 345 kV bus : 702 - j8570 MVA
- At Miami Fort 345 kV bus : 584 - j8271 MVA
- At Zimmer 345 kV bus : 564 - j9156 MVA

SECTION 6 STABILITY ANALYSIS

Table 6-1: Contingency List

Fault Location	Type of Fault	Facility out-of-service	Trip to clear	Simulation
At Miami Fort 345 kV on line to Terminal 345 kV	3-phase-to-ground with stuck breaker	none	Miami Fort 345 kV - Terminal 345 kV	StabC1
At Miami Fort 345 kV on line to West Milton 345 kV	3-phase-to-ground with stuck breaker	none	Miami Fort unit 7 Miami Fort 345 kV - W. Milton 345 kV	StabC2
At Wooddale 345 kV on line to Todhunter 2 345 kV	3-phase-to-ground with stuck breaker	none	Miami Fort unit 7 Wooddale - Todhunter 2 345 kV	StabC3
At Miami Fort 345 kV on line to West Milton 345 kV	1-phase-to-ground	Miami Fort 345 kV - Terminal 345 kV	Miami Fort 345 kV - W. Milton 345 kV	StabC4
At Wooddale 345 kV on line to Todhunter 2 345 kV	1-phase-to-ground	Wooddale 345 kV - Todhunter 1 345 kV	Wooddale - Todhunter 2 345 kV	StabC5
At Wooddale 345 kV on line to Todhunter 2 345 kV	1-phase-to-ground	Miami Fort 345 kV - Terminal 345 kV	Wooddale - Todhunter 2 345 kV	StabC6
At Zimmer 345 kV on line to Stuart 345 kV	3-phase-to-ground with stuck breaker	none	Zimmer 345 kV - Stuart 345 kV	StabC7
Open Line between Wooddale 345 kV and Todhunter 2 345 kV	Open line	Wooddale 345 kV - Todhunter 1 345 kV	Zimmer 345 kV - Silver Grove 345 kV	StabC8

6.2 Results

Appendix E contains stability plots illustrating system response to valid contingencies from Table 6-1 without the Madison II plant. Appendix F contains stability plots illustrating system response to the applied contingencies with Madison II online. Though for all the cases, the system response is stable and positively damped it is noted, damping of oscillations following the disturbance can be fairly low. These results are based on the preliminary dynamic data provided by the merchant plant developer and their equipment vendors. These results could change based on final test data and adjustment of the proposed excitation system parameters. Should the merchant plant developer proceed with the project, Cinergy will work with the merchant plant developer to implement equipment adjustments that will allow the proposed generation to connect to Cinergy's transmission system in a reliable manner. Further stability studies by Cinergy will be required based on the final dynamic data that have been obtained from the original equipment tests and/or settings.

Section

7

Short Circuit Analysis

Fault Current

The addition of 640 MW to the Woodsdale 345 kV Substation bus will increase fault current to several breakers in the area but will not cause any to exceed their fault duty ratings. The following is a breakdown of the fault currents in the immediate area of Cinergy's Woodsdale Generating Station with and without the addition of the merchant plant.

	Symmetrical Rating (MVA)	Without CT's Fault (MVA) 3-Phase		With CT's Fault (MVA)	
		3-Phase	Phase-Grd	3-Phase	Phase-Grd
Foster 138	10,000	6,665	6,209	6,680	6,235
Miami Fort 345	30,000	16,538	14,061	16,549	14,076
Port Union 138-1	10,000	8,803	7,893	8,812	7,916
Port Union 138-2	10,000	7,245	6,712	7,255	6,735
Port Union 345	25,000	19,112	15,550	19,027	15,552
Todhunter 138	15,000	11,654	11,799	11,570	11,784
Todhunter 345	30,000	17,997	16,288	17,177	15,922
Foster 345	25,000	22,326	17,088	22,075	17,050
Woodsdale	30,000	16,887	16,565	17,912	17,106

Conclusions

This report summarizes power flow and stability analyses conducted by Power Technologies, Inc. (PTI) for Cinergy Services, Inc (Cinergy) to assess the impact of the proposed Madison II 640 MW generating station. Contingency analysis identified some local transmission loading problems which result from adding the Madison II plant into the system. System upgrades, which will be necessary to integrate the requested 640 MW capacity, were identified. The estimated cost of these upgrades is \$33,807,000.

Power transfer capability was estimated from the proposed merchant plant to several neighboring control areas. These estimates are not Available Transfer Capabilities (ATC) or Total Transfer Capability (TTC) as required in FERC Order 888 and 889. Actual ATC's would be determined upon request for transmission service per Cinergy's OATT.

Short circuit calculations show that the addition of 640 MW to the Woodsdale 345 kV Substation bus will increase fault current to several breakers in the area but will not cause any to exceed their fault duty ratings.

Dynamic simulations were performed to assess system performance with and without the plant. Though for all the cases, the system response is stable and positively damped it is noted, damping of oscillations following the disturbance can be fairly low. These results are based on the preliminary dynamic data provided by the merchant plant developer and their equipment vendors. These results could change based on final test data and adjustment of the proposed excitation system parameters. Should the merchant plant developer proceed with the project, Cinergy will work with the merchant plant developer to implement equipment adjustments that will allow the proposed generation to connect to Cinergy's transmission system in a reliable manner. Further stability studies by Cinergy will be required based on the final dynamic data that have been obtained from the original equipment tests and/or settings.

POWER TECHNOLOGIES
A Shaw Group Company

Proposed Interconnection Diagram

To Woodsdale 345 kV Bus

**One-Line Diagram of the Madison II 640 MW Merchant Plant Facility
Connected to the Woodsdale 345 kV Substation.**

POWER TECHNOLOGIES
A Shaw Group Company

Plant Data Summary

APPENDIX B PLANT DATA SUMMARY

General		Comments
Maximum Gross MW Output of Unit	86.5 MW	Estimated
Total Plant Aux Power Requirements (MW, MVA)		
Step-Up Three Winding Transformer		Similar to Madison transformer
Rated Voltage on HV side	345 kV	
Rated Voltage on LV side	13.8 kV	
Rated Voltage on TV side	13.8 kV	
Rated Power HV	240	
Rated Power LV	120	
Rated Power TV	120	
Z1(primary – medium point equivalent)	0.00557	
Z2 (secondary – medium point equivalent).)	0.0001	
Z3 (terciary – medium point equivalent).)	0.0001	
GAS GENERATOR DATA		
Generator (p. u. reactances are on rated MVA, kV values)		
Model	GENROU	
Rated MVA	101.8	Estimated
Rated kV	13.8 kV	Estimated
Power factor	0.85	Estimated
H (turbine + generator inertia constant)	5.6	
X2 (Unsaturated negative sequence reactance)	0.146	
X0 (Unsaturated zero sequence reactance)	0.074	
Xd (direct axis synchronous reactance (unsaturated))	1.98	
Xd' (direct axis transient reactance (unsaturated))	0.208	
Xd'' (direct axis subtransient reactance (unsaturated))	0.15	
T'do (direct axis open-circuit transient time constant)	12.8	
T''do (direct axis open-circuit sub-transient time constant)	0.05	
Xq (quadrature axis synchronous reactance (unsaturated))	1.81	
Xq' (quadrature axis transient reactance (unsaturated))	0.30	
Xq'' (quadrature axis subtransient reactance (unsaturated))	0.15	
T'qo (quadrature axis open-circuit transient time constant)	3.9	
T''qo (quadrature axis open-circuit sub-transient time constant)	0.05	
XL (stator leakage reactance)	0.1	
R1 (positive sequence armature resistance)	0.00303	
R2 (Negative sequence armature resistance)	0.0186	
R0 (Zero sequence armature resistance)	0.0045	
Turbine and Governor		Estimated
Model	GAST2A	
Parameters		
W – governor gain (1/droop) (on turbine rating)	25	
X (sec) governor lead time constant	0	

APPENDIX B PLANT DATA SUMMARY

Y (sec) (>0.) governor lag time constant	0.02	
Z – governor mode	1	
1 – Droop		
0 – ISO		
E_{TD} (sec)	0.04	
T_{CD} (sec)	0.2	
T_{RATE} (MW)	86	
T (sec)	0	
MAX (pu limit (on turbine rating)	1.2	
MIN (pu) limit (on turbine rating)	-0.1	
E_{CR} (sec)	0.01	
K_3	0.77	
A (>0.) valve positioner	1	
B (sec) (> 0.) valve positioner	0.05	
C valve positioner	1	
τ (sec) (.0.)	0.4	
K_f	0	
K_g	0.2	
K_h	0.8	
T_3 (sec) (>0.)	15	
T_4 (sec) (>0.)	2.5	
T_r (sec) (>0.)	1650	
T_5 (sec) (>0.)	3.3	
a_1	1075	
b_1	550	
a_2	-0.201	
b_2	1.3	
c_2	0.5	
Rated Temperature T_R (°F)	1100	
Minimum fuel flow K_g (pu)	0.23	
Temperature control T_c (°F)	1100	
Miscellaneous		
Out-Of Step Relaying		Not modeled
Automatic Voltage Regulator and Excitation System		
"Type (e.g., static, brushless, etc.)"		Provided
Model	EXAC2	
Parameters		
T_R (sec)	0.01	
T_B (sec)	1	
T_C (sec)	1	
K_A	1000	
T_A (sec)	0.01	
V_{MAX}	7.3	
V_{MIN}	-7.3	
K_B	1	
V_{RMAX}	29.8	
V_{RMIN}	-29.8	
$T_E > 0$ (sec)	1.3	

APPENDIX B PLANT DATA SUMMARY

K_L	4	
K_H	0	
K_F	0.05	
$T_F > 0$ (sec)	1	
K_G	0.1	
K_D	0.78	
K_E	1	
V_{LR}	9.47	
E_1	3.06	
SE_1	0.01	
E_2	4.08	
SE_2	0.01	
Power System Stabilizer		Provided
Model	PSS2A	
Parameters		
$T_{W1} (>0)$	2	
T_{W2}	2	
T_8	0	
$T_{W3} (>0)$	2	
T_{W4}	0	
T_7	2	
K_{S2}	0.19	
K_{S3}	1	
T_8	0.5	
$T_9 (>0)$	0.1	
K_{S1}	30	
T_1	0.15	
T_2	0.03	
T_3	0.15	
T_4	0.03	
V_{STMAX}	0.1	
V_{STMIN}	-0.1	

Machine Data File

90011	'GENROU'	G	12.800	.50000E-01	3.9000	.50000E-01
	5.6000		.00000E+00	1.9800	1.8100	.20800
	.30000		.15000	.10000	.50000E-01	.23000 /
90011	'EXAC2'	G	.10000E-01	1.0000	1.0000	1000.0
	.10000E-01		7.3000	-7.300	1.0000	29.800
	-29.80		1.3000	4.0000	.00000E+00	.50000E-01
	1.0000		.10000	.78000	1.0000	9.4700
	3.0600		.10000E-01	4.0800	.10000E-01	/
90011	'GAST2A'	G	25.000	.00000E+00	.20000E-01	1.0000
	.40000E-01		.20000	86.00	.00000	1.2000
	-.15000		.10000E-01	.77000	1.0000	.50000E-01
	1.0000		.40000	.00000E+00	.20000E+00	.80000
	15.000		2.5000	1650.0	3.3000	1075.0
	550.00		-.20100	1.3000	.50000	1100.0
	.23000		1100.0 /			
90011	'PSS2A'	G	2 90000	3 0	5 1	
	2.0000		2.0000	.00000E+00	2.0000	.00000E+00
	2.0000		.19000	1.0000	.50000	.10000
	30.000		.15000	.30000E-01	.15000	.30000E-01
	.10000		-.10000 /			

Appendix
C

AC Contingency Analysis Summary

AC CONTINGENCY ANALYSIS SUMMARY

FREQUENCY OF BRANCH VIOLATIONS

Madison II Off-Line vs Madison II On-Line without Reinforcements

Monitored Branches				Madison II Off-Line			Madison II On-Line No Rein.		
**	From bus	** **	TO bus	** CMT TYP	Nviol	WorstHvio% Ncon	Nviol	WorstHvio% Ncon	*
8087	CARL M2 69.0	8089	CARLISLE 69.0	1 LN	1	111.6	2	3	123.1
8087	CARL M2 69.0	8090	CARLISLE 138	1 TR	1	109.4	2	3	119.2
8089	CARLISLE 69.0	17060	090HH W.69.0	1 LN	1	107.5	2	3	127.4
8464	MILLIKIN 138	8743	TODHUNTR 138	1 LN	1	110.0	4	2	172.7
8052	BETHANY 138	8708	TAP 5485	1 LN			1	110.8	3
8411	M.FORT 345	8717	TERMINL 345	1 LN			1	129.4	1
8411	M.FORT 345	8872	WOODSDLE 345	1 LN			1	136.6	1
8464	MILLIKIN 138	8576	P.UN 2 138	1 LN			2	158.8	3
8575	P.UN 1 138	8743	TODHUNTR 138	1 LN			2	170.6	3
8587	PARK 1 138	8589	PARK 2 138	1 LN			1	111.3	3
8708	TAP 5485	138	8743	TODHUNTR 138	1 LN		2	131.8	3
8735	TOD M15 138	8743	TODHUNTR 138	1 TR			2	126.9	3
8735	TOD M15 138	8744	TODHUNTR 345	1 TR			2	129.6	3
8736	TOD M16 138	8743	TODHUNTR 138	1 TR			2	132.4	3
8736	TOD M16 138	8744	TODHUNTR 345	1 TR			2	135.6	3
8737	TOD M17 138	8743	TODHUNTR 138	1 TR			2	116.7	3
8737	TOD M17 138	8744	TODHUNTR 345	1 TR			2	119.6	3
8744	TODHUNTR 345	8872	WOODSDLE 345	1 LN					
8744	TODHUNTR 345	8872	WOODSDLE 345	2 LN					
8741	TODHUNTR 69	8792	TX E MN69 69	2 LN					

* Following is the list of contingencies used in this analysis

1. Woodsdale to TodHunter ckt 1 & Woodsdale to TodHunter ckt 2 345 kV
2. Poster to Sugar Creek & Poster to Bath 345 kV
3. Woodsdale to Miami Fort & TodHunter to Foster 345 kV
4. Miami Fort to Terminal & TodHunter to Foster 345 kV
5. Woodsdale to TodHunter 345 kV Ckt 2
6. Woodsdale to TodHunter 345 kV Ckt 1
7. Tap 5485 to Union 138 kV

Appendix
D

Linear Transfer Analysis Summary

Pre-Transfer Overloads

Monitored Branches	Number of Violations	Worst Violation (%)
6007 11MIDDLT 345 6117 11MIDDLT 138 1	1	14.8
6007 11MIDDLT 345 6117 11MIDDLT 138 2	1	11.0
11003 06SARGNT 138 11004 06DOE530 345 1	9	5.4

LINEAR TRANSFER ANALYSIS SUMMARY

Transfer Analysis Without Reinforcement		Limiting Constraint		Contingency		Neon	PreShift	Rating
To	FCITC							
AEP	229.5	8744	TODHUNTR 345	8872 WOODSDLE 345 2	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 1	441	-1143.5	-1315
	229.5	8744	TODHUNTR 345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 2	442	-1143.5	-1315
	363.9	8464	MILLIKIN 138	8743 TODHUNTR 138 1	C: 8281 FOSTER 345 8744 TODHUNTR 345 1	352	-196.6	-246
	548.3	8575	P UN 1 138	8743 TODHUNTR 138 1	C: 8281 FOSTER 345 8744 TODHUNTR 345 1	352	-161.1	-246
	618.8	8464	MILLIKIN 138	8576 P UN 2 138 1	C: 8281 FOSTER 345 8744 TODHUNTR 345 1	352	161.9	246
	229.9	8744	TODHUNTR 345	8872 WOODSDLE 345 2	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 1	441	-1143.5	-1315
AMRN	229.9	8744	TODHUNTR 345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 2	442	-1143.5	-1315
	360.9	8464	MILLIKIN 138	8743 TODHUNTR 138 1	C: 8281 FOSTER 345 8744 TODHUNTR 345 1	352	-196.6	-246
	539.4	8575	P UN 1 138	8743 TODHUNTR 138 1	C: 8281 FOSTER 345 8744 TODHUNTR 345 1	352	-161.1	-246
	613.9	8464	MILLIKIN 138	8576 P UN 2 138 1	C: 8281 FOSTER 345 8744 TODHUNTR 345 1	352	161.9	246
	229.9	8744	TODHUNTR 345	8872 WOODSDLE 345 2	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 1	441	-1143.5	-1315
DPL	113.8	8741	TODHUNTR169.0	8792 TX E MNR69.0 1	C: 8708 TAP 5485 138 8797 UNION 138 1	430	95	101
	145.1	8758	TP5666-169.0	8792 TX E MNR69.0 1	C: 8708 TAP 5485 138 8797 UNION 138 1	430	-93.3	-101
	149.3	8353	JACKSON 69.0	8758 TP5666-169.0 1	C: 8708 TAP 5485 138 8797 UNION 138 1	430	-93.1	-101
	196.8	8741	TODHUNTR169.0	8792 TX E MNR69.0 1	C: 8090 CARLISLE 138 8797 UNION 138 1	291	90.6	101
	215.3	8087	CARL M2 69.0	8089 CARLISLE69.0 1	C:17079 09SUGRCK 345 8281 FOSTER 345 1	1723	145.6	168
	223.7	8744	TODHUNTR 345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 2	442	-1143.5	-1315
	228.1	8758	TP5666-169.0	8792 TX E MNR69.0 1	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 1	441	-1143.5	-1315
	228.3	8087	CARL M2 69.0	8090 CARLISLE 138 1	C: 8090 CARLISLE 138 8797 UNION 138 1	291	-88.9	-101
	232.3	8353	JACKSON 69.0	8758 TP5666-169.0 1	C:17079 09SUGRCK 345 8281 FOSTER 345 1	1723	-161.2	-185
	229.5	8744	TODHUNTR 345	8872 WOODSDLE 345 1	C: 8090 CARLISLE 138 8797 UNION 138 1	291	-88.7	-101
EKPC	229.5	8744	TODHUNTR 345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 2	442	-1143.5	-1315
	255.2	6051	ILADAMS 138	6146 ILTYRONE 138 1	C: 8744 TODHUNTR 345 8872 WOODSDLE 345 1	441	-1143.5	-1315
	299.2	6064	ILBRWN P 138	6087 ILPAWES 138 1	C: 6126 ILLOC TAP 138 6137 ILSCOTT 138 1	1639	-91.3	-97
	347.8	6064	ILBRWN P 138	6087 ILPAWES 138 1	C:20007 20AVON 138 20027 20BOONST 138 1	146	162.6	219
	359.9	8464	MILLIKIN 138	8743 TODHUNTR 138 1	C: 6002 ILALCALD 345 6004 ILBRWN N 345 1	1450	173.8	219
	404.9	20007	20AVON 138	20027 20BOONST 138 1	C: 8281 FOSTER 345 8744 TODHUNTR 345 1	352	-196.6	-246
	419.8	6064	ILBRWN P 138	6087 ILPAWES 138 1	C: 6064 ILBRWN P 138 6087 ILPAWES 138 1	1562	130.3	222
	519.5	6064	ILBRWN P 138	6087 ILPAWES 138 1	C:20027 20BOONST 138 20065 20DALE 138 1	1415	137.5	219
	528.1	6064	ILBRWN P 138	6087 ILPAWES 138 1	C: 6064 ILBRWN P 138 6065 ILBRWNNT1 138 1	1560	-236	-297
	528.1	6064	ILBRWN P 138	6087 ILPAWES 138 1	C:20065 20DALE 138 20287 20TRU 138 1	1423	163.3	219
	528.1	6064	ILBRWN P 138	6087 ILPAWES 138 1	C:20065 20DALE 138 20287 20TRU 138 1	1423	163.3	219

LINEAR TRANSFER ANALYSIS SUMMARY

HE	230.2	8744	TODHUNTR	345	8872	WOODSDLE	345	2	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	1	441	-1143.5	-1315			
	230.2	8744	TODHUNTR	345	8872	WOODSDLE	345	1	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	2	442	-1143.5	-1315			
	358.6	8464	MILLIKIN	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-196.6	-246			
	532.8	8575	P.UN 1	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-161.1	-246			
	587.2	4002	16PETE	345	4042	16PETE	138	E	C: 23	GIBSON	345	180	GIBSON	138	1	43	126.9	180			
	590.7	4002	16PETE	345	4042	16PETE	138	E	C: 178	PRINCETO	138	180	GIBSON	138	1	212	126.5	180			
	602.6	4002	16PETE	345	4042	16PETE	138	E	C: 4002	16PETE	345	4042	16PETE	138	W	579	116.5	180			
	609.9	8464	MILLIKIN	138	8576	P.UN 2	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	161.9	246			
IPL	230.4	8744	TODHUNTR	345	8872	WOODSDLE	345	2	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	1	441	-1143.5	-1315			
	230.4	8744	TODHUNTR	345	8872	WOODSDLE	345	1	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	2	442	-1143.5	-1315			
	358.7	8464	MILLIKIN	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-196.6	-246			
	532.8	8575	P.UN 1	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-161.1	-246			
	610	8464	MILLIKIN	138	8576	P.UN 2	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	161.9	246			
LGEE	27.9	24	SPEED	345	156	SPEED	138	1	C: 6005	11GHENT	345	6015	11W	LEXN	345	1	1461	477.1	478		
	112.3	24	SPEED	345	156	SPEED	138	1	C: 7064	05JERSO	765	7068	05ROCKPT	765	1	538	475.1	478			
	229.6	8744	TODHUNTR	345	8872	WOODSDLE	345	2	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	1	441	-1143.5	-1315			
	229.6	8744	TODHUNTR	345	8872	WOODSDLE	345	1	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	2	442	-1143.5	-1315			
	229.8	24	SPEED	345	156	SPEED	138	1	C: 6007	11MIDDLT	345	6013	11TRIMBL	345	1	1466	461.7	478			
	356.9	8464	MILLIKIN	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-196.6	-246			
	425.8	6075	11CENTRP	138	6145	11TRIMBL	138	1	C: 6007	11MIDDLT	345	6013	11TRIMBL	345	1	1466	-182.3	-215			
	525.1	6013	11TRIMBL	345	6145	11TRIMBL	138	1	C: 6007	11MIDDLT	345	6013	11TRIMBL	345	1	1466	183.7	224			
	528.4	8575	P.UN 1	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-161.1	-246			
	551.9	6064	11BRWN	P	138	6154	11WC-DD	138	1	C: 6064	11BRWN	P	138	6148	11W	CLIF	138	1	1564	162.9	182
NIPS	230.2	8744	TODHUNTR	345	8872	WOODSDLE	345	2	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	1	441	-1143.5	-1315			
	230.2	8744	TODHUNTR	345	8872	WOODSDLE	345	1	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	2	442	-1143.5	-1315			
	362.7	8464	MILLIKIN	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-196.6	-246			
	543.5	8575	P.UN 1	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-161.1	-246			
	616.9	8464	MILLIKIN	138	8576	P.UN 2	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	161.9	246			

LINEAR TRANSFER ANALYSIS SUMMARY

QVEC	228.5	8744	TODHUNTR	345	8872	WOODSDLE	345	2	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	1	441	-1143.5	-1315
	228.5	8744	TODHUNTR	345	8872	WOODSDLE	345	1	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	2	442	-1143.5	-1315
	359.2	8464	MILLIKIN	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-196.6	-246
	538.5	8575	P UN	1	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-161.1
	610.9	8464	MILLIKIN	138	8576	P UN	2	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	246
SIGE	153.7	1064	TETC	12J69.0	1066	PRINCETO	69.0	1	C: 175	OAK CITY	138	178	PRINCETO	138	1	211	-37.5	-44
	200.5	1058	OAKLAND	69.0	1064	TETC	12J69.0	1	C: 175	OAK CITY	138	178	PRINCETO	138	1	211	-35.5	-44
	229.5	1058	OAKLAND	69.0	3247	100AKTY	69.0	1	C: 3251	LOTOTOYA	138	175	OAK CITY	138	1	1677	16.9	39
	230	8744	TODHUNTR	345	8872	WOODSDLE	345	1	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	2	442	-1143.5	-1315
	230	8744	TODHUNTR	345	8872	WOODSDLE	345	2	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	1	441	-1143.5	-1315
	348.4	178	PRINCETO	138	1066	PRINCETO	69.0	1	C: 175	OAK CITY	138	178	PRINCETO	138	1	211	54.3	69
	358.5	8464	MILLIKIN	138	8743	TODHUNTR	138	1	C: 8281	FOSTER	345	8744	TODHUNTR	345	1	352	-196.6	-246
	373.9	4002	16PETE	345	4042	16PETE	138	E	C: 23	GIBSON	345	180	GIBSON	138	1	43	126.9	180
	376.1	4002	16PETE	345	4042	16PETE	138	E	C: 178	PRINCETO	138	180	GIBSON	138	1	212	126.5	180
	383	1058	OAKLAND	69.0	3247	100AKTY	69.0	1	C: 175	OAK CITY	138	178	PRINCETO	138	1	211	12.4	39

TRANSFER ANALYSIS

[illegible]

LINEAR TRANSFER ANALYSIS SUMMARY

HE	-1627.5	17089	09WMILTN 138	17090	09WMILTN 345 1	C: 17047 09MIAMI 345	17090	09WMILTN 345 1	1374	-626.5	-495
	591.7	4002	16PETE	345	4042 16PETE 138 E	C: 23 GIBSON 345	180	GIBSON 138 1	43	126.4	130
	595.2	4002	16PETE	345	4042 16PETE 138 E	C: 178 PRINCETO 138	180	GIBSON 138 1	212	126.1	140
	603.4	17047	09MIAMI	345	17090 09WMILTN 345 1	C: 17089 09WMILTN 138	17090	09WMILTN 345 1	1371	-1176.1	-1315
	607	4002	16PETE	345	4042 16PETE 138 E	C: 4002 16PETE 345	4042	16PETE 138 W	582	116.1	130
	624.3	8744	TODHUNTR	345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 2	443	-979.8	-13.5
	624.3	8744	TODHUNTR	345	8872 WOODSDLE 345 2	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 1	442	-979.8	-13.5
	711.5	2020	07VCKSBG69.0	2021	07ESLVTN69.0 1	C: 2006 07RATTS 161	2116	07RATTS8 138 1	541	-10.1	-86
	856.6	2006	07RATTS	161	2116 07RATTS8 138 1	C: 7064 05JEPRSO 765	7068	05RCKPT 765 1	541	23.4	-225
	876.3	2015	07WRTHG 69.0	2020	07VCKSBG69.0 1	C: 2006 07RATTS 161	2116	07RATTS8 138 1	541	-4.1	-16
IPL	-1642.3	17089	09WMILTN 138	17090	09WMILTN 345 1	C: 17047 09MIAMI 345	17090	09WMILTN 345 1	1374	-626.5	-495
	609.7	17047	09MIAMI	345	17090 09WMILTN 345 1	C: 17089 09WMILTN 138	17090	09WMILTN 345 1	1371	-1176.1	-1315
	624.3	8744	TODHUNTR	345	8872 WOODSDLE 345 2	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 1	442	-979.8	-1315
	624.3	8744	TODHUNTR	345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 2	443	-979.8	-1315
LGEE	-1688.4	17089	09WMILTN 138	17090	09WMILTN 345 1	C: 17047 09MIAMI 345	17090	09WMILTN 345 1	1374	-626.5	-495
	60.2	24	SPEED	345	156 SPEED 138 1	C: 6005 11GHENT 345	6015	11W LEXN 345 1	1464	476	478
	232.6	24	SPEED	345	156 SPEED 138 1	C: 6007 11MIDDLT 345	6013	11TRIMBL 345 1	1469	461.5	478
	400.3	6075	11CENTRF 138	6145	11TRIMBL 138 1	C: 6007 11MIDDLT 345	6013	11TRIMBL 345 1	1469	-184.4	-215
	499.8	6013	11TRIMBL 345	6145	11TRIMBL 138 1	C: 6007 11MIDDLT 345	6013	11TRIMBL 345 1	1469	185.8	224
	549.8	6064	11BRWN P 138	6154	11WC-DD 138 1	C: 6064 11BRWN P 138	6148	11W CLIF 138 1	1567	143	142
	607.6	6028	11GR RV 161	6094	11GR RVR 138 1	C: 6028 11GR RV 161	6094	11GR KVR 138 2	152	81.1	115
	617.9	8744	TODHUNTR	345	8872 WOODSDLE 345 2	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 1	442	-979.8	-1315
	617.9	8744	TODHUNTR	345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 2	443	-979.8	-1315
	620.7	6064	11BRWN P 138	6148	11W CLIF 138 1	C: 6064 11BRWN P 138	6154	11WC-DD 138 1	1568	196.2	222
NIPS	-1500.1	17089	09WMILTN 138	17090	09WMILTN 345 1	C: 17047 09MIAMI 345	17090	09WMILTN 345 1	1374	-626.5	-495
	550.1	17047	09MIAMI	345	17090 09WMILTN 345 1	C: 17089 09WMILTN 138	17090	09WMILTN 345 1	1371	-1176.1	-1315
	636.8	8744	TODHUNTR	345	8872 WOODSDLE 345 2	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 1	442	-979.8	-1315
	636.8	8744	TODHUNTR	345	8872 WOODSDLE 345 1	C: 8744 TODHUNTR 345	8872	WOODSDLE 345 2	443	-979.8	-1315
	962.7	17047	09MIAMI	345	17090 09WMILTN 345 1	C: 8281 FOSTER 345	8744	TODHUNTR 345 1	312	-976.6	-1315

OVEC	-1649.6	17089	09WMILTN	138	17090	09WMILTN	345	1	C:17047	09MIAMI	345	17090	09WMILTN	345	1	1374	-626	5	-435
	610	17047	09MIAMI	345	17090	09WMILTN	345	1	C:17089	09WMILTN	138	17090	09WMILTN	345	1	1341	-1176	1	-1315
	614.8	8744	TODHUNTR	345	8872	WOODSDLE	345	2	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	1	442	-979	8	-1315
	614.8	8744	TODHUNTR	345	8872	WOODSDLE	345	1	C: 8744	TODHUNTR	345	8872	WOODSDLE	345	2	443	-979	8	-1315
SIGE	-1622.9	17089	09WMILTN	138	17090	09WMILTN	345	1	C:17047	09MIAMI	345	17090	09WMILTN	345	1	1374	-626	5	-435
	154.9	1064	TETC	12JG9.0	1066	PRINCETO69.0	1	C:	175	OAK CITY	138	178	PRINCETO	138	1	21	-37	4	-4
	201.8	1058	OAKLAND	69.0	1064	TETC	12JG9.0	1	C:	175	OAK CITY	138	178	PRINCETO	138	1	211	-35	5
	230.9	1058	OAKLAND	69.0	3247	100AKCTY69.0	1	C:	3251	10TOYOTA	138	175	OAK CITY	138	1	1681	16	8	39
	349.7	178	PRINCETO	138	1066	PRINCETO69.0	1	C:	175	OAK CITY	138	178	PRINCETO	138	1	21	54	2	69
	376.7	4002	16PETE	345	4042	16PETE	138	E	C:	23	GIBSON	345	180	GIBSON	138	1	43	126	4
	379	4002	16PETE	345	4042	16PETE	138	E	C:	178	PRINCETO	138	180	GIBSON	138	1	212	126	1
	384.4	1058	OAKLAND	69.0	3247	100AKCTY69.0	1	C:	175	OAK CITY	138	178	PRINCETO	138	1	21	12	3	9
	402.6	1058	OAKLAND	69.0	3247	100AKCTY69.0	1	C:	2150	07RAMSV5	345	23	GIBSON	345	1	1671	12	7	39
	414.9	174	OLDHENJT	138	4042	16PETE	138	1	C:	23	GIBSON	345	180	GIBSON	138	1	43	-81	1
																			-146



POWER TECHNOLOGIES
A Shaw Group Company



Appendix
E

Transient Stability Analysis

Madison II Off line


MADISON II OFF LINE : SIMULATION: RUN STABC1

RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25577 MIAMI FORT 345 kV /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25577 MIAMI FORT 345 kV through ADMITTANCE 584.0 -
8271.0 MVA /STUCK BREAKER
TRIP LINE FROM BUS 25577 MIAMI FORT TO 25736 TERMINAL CIRCUIT 1 /
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
DROP GENERATOR 25912 MIAMI FORT #7 /BACKUP
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END




RUN STABCI PLOT 1


 MADISON II 640 HY PROJECT SP DYNAMIC CASE
 MADISON II OFF LINE
 THREE P. FRONT AT MINKI P. 345 HY ON LINE TO TERMINAL
 FILE: C:\civeng\yoodsdale\cinstabno\channel_output\STABCI.out




FRI, OCT 31 1997 6:59
 MADISON II M. FORT 7 VT &


 MADISON II 640 HY PROJECT SP DYNAMIC CASE
 MADISON II OFF LINE
 THREE P. FRONT AT MINKI P. 345 HY ON LINE TO TERMINAL
 FILE: C:\civeng\yoodsdale\cinstabno\channel_output\STABCI.out



FRI, OCT 31 1997 6:59
 PSI MACHINES - VTERM



RUN STABCI PLOT 2





RUN STABC1 PLOT 3

MADISON II OFF LINE : SIMULATION: RUN STABC2


```
RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25577 MIAMI FORT 345 kv  /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25577 MIAMI FORT through ADMITTANCE 584.0 -8271.0 MVA
/STUCK BREAKER
TRIP LINE FROM BUS 25577 MIAMI FORT TO BUS 26661 WEST MILTON CIRCUIT 1
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
DROP GENERATOR BUS 25912 MIAMI FORT #7 /BACKUP
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```



RUN STABC2 PLOT 1



RUN STABC2 PLOT 2




RUN STABC2 PLOT 3

MADISON II OFF LINE : SIMULATION: RUN STABC3


RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25824 WOODSDALE 345 kV /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25824 WOODSDALE through ADMITTANCE 702.0 -8570.0 MVA
/STUCK BREAKER
TRIP LINE FROM BUS 25824 WOODSDALE TO 25755 TODHUNTER CIRCUIT 2 /BACKUP
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END

MADISON II 540 MN PROJECT SP DYNAMIC CASE
 MADISON II OFF LINE
 TIME P. FAULT AT MADISON II 345 KV ON LINE TO 1000METER
 FILE: C:\civ\erbu\woods\data\civ\instab\channel_output\STABC3.out




FRI, OCT 31 1997 7:05
 MADISON II M. FORT 7 VT &

MADISON II 540 MN PROJECT SP DYNAMIC CASE
 MADISON II OFF LINE
 TIME P. FAULT AT MADISON II 345 KV ON LINE TO 1000METER
 FILE: C:\civ\erbu\woods\data\civ\instab\channel_output\STABC3.out



FRI, OCT 31 1997 7:05
 PSI MACHINES - VTERM



RUN STABC3 PLOT 2




RUN STABC3 PLOT 3

MADISON II OFF LINE : SIMULATION: RUN STABC4

```
RUN TO .5 SECONDS PRINT 0 PLOT 1
/MAIMI FORT - TERMINAL OUT OF SERVICE
APPLY FAULT AT BUS 25577 MIAMI FORT through ADMITTANCE 584.0 -8271.0 MVA
/SINGLE PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25577 MIAMI FORT TO BUS 26661 WEST MILTON CIRCUIT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```



RUN STABC4 PLOT 2





RUN STABC4 PLOT 3

MADISON II OFF LINE : SIMULATION: RUN STABC5

RUN TO .5 SECONDS PRINT 0 PLOT 1
/WOODSDALE-TODHUNTER CIRCUIT 1 345 kV OUT OF SERVICE
APPLY FAULT AT BUS 25824 WOODSDALE through ADMITTANCE 702.0 -8570.0 MVA
/SINGLE PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25824 WOODSDALE TO BUS 25755 TODHUNTER CIRCUIT 2
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END



RUN STABCS PLOT 1





RUN STABCS PLOT 2




MADISON II OFF LINE : SIMULATION: RUN STABC6

RUN TO .5 SECONDS PRINT 0 PLOT 1
/MIAMI FORT-TERMINAL 345 KV OUT OF SERVICE
APPLY FAULT AT BUS 25824 WOODSDALE through ADMITTANCE 702.0 -8570.0 MVA
/SINGLE PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25824 WOODSDALE TO BUS 25755 TODHUNTER CIRCUIT 2
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END





RUN STABC6 PLOT 2




E-25

MADISON II OFF LINE : SIMULATION: RUN STABC7


```
RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25830 ZIMMER /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25830 ZIMMER through ADMITTANCE 564.0 -9156.0 MVA
/STUCK BREAKER
TRIP LINE FROM BUS 25830 ZIMMER TO BUS 26648 STUART CIRCUIT 1
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25830 ZIMMER TO BUS 25692 S. GROVE CIRCUIT 1 /BACK UP
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```

RUN STABC7 PLOT 1





RUN STABC7 PLOT 3





RUN STABC7 PLOT 3


MADISON II OFF LINE : SIMULATION: RUN STABC8


RUN TO .5 SECONDS PRINT 0 PLOT 1
/WOODSDALE - TODHUNTER OUT OF SERVICE
TRIP LINE FROM BUS 25824 WOODSDALE TO BUS 25755 TODHUNTER CIRCUIT 2
/OPEN CIRCUIT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END





RUN STAB8 PLOT 2







POWER TECHNOLOGIES
A Shaw Group Company



Appendix
F



Stability Analysis Simulation Results: Madison II On-Line


MADISON II ONLINE : SIMULATION: RUN STABC1

```
RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25577 MIAMI FORT 345 KV      /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25577 MIAMI FORT through ADMITTANCE 584.0 -8271.0 MVA
/STUCK BREAKER
TRIP LINE FROM BUS 25577 MIAMI FORT TO BUS 25736 TERMINAL CIRCUIT 1 /
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
DROP GENERATOR BUS 25912 MIAMI FORT #7      /BACKUP
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```












MADISON II ONLINE : SIMULATION: RUN STABC2



```
RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25577 MIAMI FORT /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25577 MIAMI FORT through ADMITTANCE 584.0 -8271.0 MVA
/STUCK BREAKER
TRIP LINE FROM BUS 25577 MIAMI FORT TO BUS 26661 WEST MILTON CIRCUIT 1
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
DROP GENERATOR BUS 25912 MIAMI FORT #7 /BACKUP
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```







MADISON II ONLINE : SIMULATION: RUN STABC3



```
RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25824 WOODSDALE /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25824 WOODSDALE through ADMITTANCE 702.0 -8570.0 MVA
/STUCK BREAKER
TRIP LINE FROM BUS 25824 WOODSDALE TO BUS 25755 TODHUNTER CIRCUIT 2 /BACKUP
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```




RUN STABC3 PLOT 1



RUN STABC3 PLOT 2



RUN STABC3 PLOT 3





PSI 345 KV LINES
 THREE PHASE FAULT AT PSI 345 KV ON LINE TO TIDWATER
 FILE: C:\CINEMA\97\00000000\cinema\channel_output\51M03.out



THU, OCT 30 1997 17:35
 PSI 345 KV LINES POWER FL

MADISON II ONLINE : SIMULATION: RUN STABC4


RUN TO .5 SECONDS PRINT 0 PLOT 1
/MAIMI FORT-TERMINAL OUT OF SERVICE
APPLY FAULT AT BUS 25577 MIAMI FORT through ADMITTANCE 584.0 -8271.0 MVA
/SINGLE PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25577 MIAMI FORT TO BUS 26661 WEST MILTON CIRCUIT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END



RUN STABC4 PLOT 2





RUN STABC4 PLOT 3




RUN STAB4 PLOT 4

MADISON II ONLINE : SIMULATION: RUN STABC5

```
RUN TO .5 SECONDS PRINT 0 PLOT 1
/WOODSDALE-TODHUNTER CIRCUIT 1 345 KV OUT OF SERVICE
APPLY FAULT AT BUS 25824 WOODSDALE through ADMITTANCE 702.0 -8570.0 MVA
/SINGLE PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25824 WOODSDALE TO BUS 25755 TODHUNTER CIRCUIT 2
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```



RUN STABCS PLOT 3





F-26

MADISON II ONLINE : SIMULATION: RUN STABC6



RUN TO .5 SECONDS PRINT 0 PLOT 1
/MIAMI FORT-TERMINAL 345 KV OUT OF SERVICE
APPLY FAULT AT BUS 25824 WOODSDALE through ADMITTANCE 702.0 -8570.0 MVA
/SINGLE PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25824 WOODSDALE TO BUS 25755 TODHUNTER CIRCUIT 2
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END




RUN STABC6 PLOT 1



RUN STAB6 PLOT 2





RUN STABC6 PLOT 3





RUN STABC6 PLOT 4

MADISON II ONLINE : SIMULATION: RUN STABC7


```
RUN TO .5 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 25830 ZIMMER /3 PHASE FAULT
RUN FOR 3.75 CYCLES PRINT 0 PLOT 1
CLEAR FAULT
APPLY FAULT AT BUS 25830 ZIMMER through ADMITTANCE 564.0 -9156.0 MVA
/STUCK BREAKER
TRIP LINE FROM BUS 25830 ZIMMER TO BUS 26648 STUART CIRCUIT 1
RUN FOR 6.0 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 25830 ZIMMER BUS 25692 S.GROVE CIRCUIT 1 /BACK UP
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END
```

RUN STABCT PLOT 2





RUN STABC7 PLOT 3





RUN STABC7 PLOT 4

WOODSDALE ONLINE : SIMULATION: RUN STABC8

RUN TO .5 SECONDS PRINT 0 PLOT 1
/WOODSDALE -TODHUNTER OUT OF SERVICE
TRIP LINE FROM BUS 25824 WOODSDALE TO BUS 25755 TODHUNTER CIRCUIT 2
/OPEN CIRCUIT
RUN TO 5 SECONDS PRINT 0 PLOT 3
RUN TO 10 SECONDS PRINT 0 PLOT 7
END



RUN STAB8 PLOT 1



RUN STABC8 PLOT 2

