

FILE

03-2390-WS-AIR²

04-339-WW-AAH

RECEIVED-DOCKETING DIV

2005 2005 JUL -8 PM 1:30

OHIO AMERICAN WATER COMPANY
MARION - DISTRICT

EFFLUENT HARDNESS / MG/L

PUCO

June	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	407	151
2	418	152
3	418	153
4	433	149
5	455	152
6	443	139
7	428	144
8	428	143
9	430	145
10	425	142
11	423	148
12	455	159
13	485	134
14	470	156
15	475	166
16	445	146
17	430	134
18	460	147
19	470	148
20	458	133
21	441	131
22	432	135
23	478	151
24	486	135
25	498	146
26	511	141
27	460	143
28	404	129
29	395	133
30	413	143

AVERAGE	446	144
MAX	511	166
MIN	395	129

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician AH Date Processed JUL 8 2005

**JUNE 2005
EFFLUENT HARDNESS AVG-144 MG/L
MARION DISTRICT**

