

FILE

03-2390-WS-AIR
04-339-WW-AAM

PUCO

2005 APR 20 AM 9:58

RECEIVED-DOCKETING DIV

Ohio American Water Co.
Franklin County Operations
Lake Darby Water Treatment Plant
PWSID#2502612

Reporting Period March 2005

Total Hardness*

Date	Day of Week	Flow (MGD)	Plant Concentration (mg/l)*	Central Laboratory Concentration (mg/l)*
1	Tuesday	0.249	138	134
2	Wednesday	0.362	136	132
3	Thursday	0.231	83	53
4	Friday	0.295	117	98
5	Saturday	0.290	120	97
6	Sunday	0.288	112	107
7	Monday	0.289	103	103
8	Tuesday	0.243	108	99
9	Wednesday	0.276	108	103
10	Thursday	0.268	111	102
11	Friday	0.241	114	99
12	Saturday	0.196	230	231
13	Sunday	0.396	180	172
14	Monday	0.276	110	106
15	Tuesday	0.256	114	96
16	Wednesday	0.298	112	96
17	Thursday	0.223	111	103
18	Friday	0.215	113	103
19	Saturday	0.341	113	102
20	Sunday	0.299	140	168
21	Monday	0.256	125	102
22	Tuesday	0.246	111	98
23	Wednesday	0.246	114	100
24	Thursday	0.222	111	104
25	Friday	0.272	110	100
26	Saturday	0.277	110	100
27	Sunday	0.281	110	106
28	Monday	0.189	113	100
29	Tuesday	0.335	113	102
30	Wednesday	0.208	113	102
31	Thursday	0.272	113	104
Min.		0.189	83	53
Max		0.396	230	231
Average		0.27	120	110
% Above 150 mg/l			6.5	9.7
% Below 130 mg/l			83.9	83.9

*All Hardness analyses were done using Standard Methods, 20th Ed., Method 2340c (Hardness as CaCO₃)
Plant concentrations are based on a daily average.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician *TS* Date Processed 4-20-05