

OHIO AMERICAN WATER COMPANY
 MARION - DISTRICT

2006

EFFLUENT HARDNESS / MG/L

August	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	400	144
2	403	154
3	413	154
4	372	153
5	363	140
6	389	147
7	416	147
8	385	146
9	384	139
10	419	151
11	426	146
12	430	142
13	448	150
14	445	144
15	437	145
16	437	142
17	450	140
18	475	146
19	475	139
20	459	139
21	435	141
22	410	139
23	480	152
24	540	150
25	540	130
26	533	133
27	520	140
28	478	147
29	463	136
30	457	131
31	462	147
AVERAGE	443	144
MAX	540	154
MIN	363	130

